

Confidential Report

2 August 2001

TECHNICAL HIGH LEVEL RISK ASSESSMENT

FOR

**FIRST NATIONAL BATTERY COMPANY
BENONI SOUTH, JOHANNESBURG, RSA**

Compiled by: _____

Eugene Pininski
Asset Management Consu

Approved by: _____

Willie Schlechter
Divisional Director

Report Summary Sheet

<p>Client:</p> <p>First National Battery Company Benoni ,South Africa</p> <p>Attention: Mr. Charles van Aswegen</p> <p>Address: First National Battery Company (Pty) Ltd. Liverpool & Bristol Roads Benoni South Republic of South Africa</p>	<p style="text-align: center;">Client Contract No.</p> <p style="text-align: center;">CUA 1206</p>
<p>Title of Report:</p> <p>Technical High Level Risk Assessment Report</p>	
<p>Summary:</p> <p>Risk Assessment of Batteries and Mining Equipment</p>	
<p>Keywords:</p> <p>First National Battery Benoni, Johannesburg Technical Risk Assessment Structured What If Technique Workshop</p>	
<p>Project Carried out By: Eugene Pininski</p>	
<p>IRCA Project No.</p>	<p>01-0235.07</p>

Document Revision Record

Rev No	Issue Date	Reason for Issue	Prepared By	Reviewed By
0	03/08/01	Risk Assessment Report	EP	WS

CONTENTS

SECTION 1	INTRODUCTION
SECTION 2	EXECUTIVE SUMMARY
SECTION 3	RISK ASSESSMENT METHODOLOGY
SECTION 4	MOTIVE POWER AND CHARGERS
SECTION 5	CHARGING RACKS
SECTION 6	UNDERGROUND ILLUMINATION
SECTION 7	TOX AND FLAM ALARMS
SECTION 8	STANDBY BATTERIES
SECTION 9	TEAM MEMBERS

SECTION 1

INTRODUCTION

SECTION 1

INTRODUCTION

1.1 OBJECTIVE

The objectives of this Risk Assessment was to:

- Facilitate a Risk Assessment, using the “What If” technique, for First National Battery in Benoni, Johannesburg (hereafter abbreviated as FNB), in July 2001, on a number of their manufactured equipment, which is used on the mines.
- Assist FNB in identifying possible hazards relating to the use of the equipment, and in order that the Mine Health and Safety Act, 21 of 1996 are complied with.
- Transfer knowledge to team members involved, in order that they have a better understanding of the Risk Assessment techniques and the relevant statutory requirements.

1.2 SCOPE

The scope of this assessment was confined to the following equipment:

- Motive Power Batteries and Chargers.
- Miners Cap Lamps and Charging Racks.
- Leisure Lamp and Loco Light
- Tox and Flam Alarms
- Standby Batteries

1.3 REPORTING

This particular Risk Assessment technique requires that reporting is done by exception, (Equipment discussed having **NO** risks were **NOT** recorded) and hence only equipment or articles with possible risks were recorded and have been included in this report.

1.4 ACKNOWLEDGEMENTS

IRCA is grateful for the valuable time that was made available by the FNB team for this assessment. The success of any Risk Assessment depends entirely on the correct selection and positive participation by the team members.

Secondly, appreciation is extended to FNB for arranging the facilities and refreshments for the duration of the Assessment.

1.5 TEAM MEMBERS

As per Section 13

1.6 DISCLAIMER

For each equipment one, or more, design intentions were identified. This information was contributed by the team members present at the Risk Assessment at that time and it does not necessarily indicate the only design intents, but rather the consensus opinion of the team members present at the time.

Where no hazard was identified, it does not necessarily indicate that no hazards exists. Similarly, where hazards were identified, it only reflects the opinions and experience of the team members and does not imply that no other, further hazards exist.

IRCA attempted to provide the best possible guidance to the team members in identifying possible hazards and formulating feasible recommendations, but at no stage attempted to be prescriptive.

IRCA therefore accepts no responsibility for any errors or misinterpretations that may appear in the report.

The report must be viewed as a holistic overview of possible hazards, identified by the employees themselves and contains in the recommendations only suggestions for further consideration by FNB management.

SECTION 2

EXECUTIVE SUMMARY

SECTION 2

EXECUTIVE SUMMARY

The objective of this assessment was to identify all potential hazards relating to the following FNB manufactured equipment and used on the mines.

- Motive Power Batteries and Chargers
- Miners Cap Lamps and Charging Racks
- Leisure Lamp and Loco Light
- Tox and Flam Alarms
- Standby Batteries

The purpose being, to assure that FNB defines the proper use of all equipment and that this equipment is without risk when used properly.

This executive summary contains some of the more high priority related risks, for each of the equipment, which has been extracted from the assessment database.

It is therefore recommended that these are not taken as the only risks, or are viewed in isolation, to the remainder of the report. These should be viewed in context with the other risks identified and assessed by the Risk Assessment team.

2.1 Motive Power

2.1.1 Operating and Maintenance

From the risk assessment it is recommended that the supplier Safety Rules as laid out in their Installation and Maintenance Instructions must be followed. This will help to reduce the possible risk of explosions, in particular due to the following:

- Loose connections.
- Tracking.
- Metal on connectors or terminals.
- Open flame due to welding operations etc.

It is also recommended that the FNB Installation and Maintenance and Safety Instructions to be included in each delivery of equipment. This will help to ensure users are aware of the safety rules.

2.1.2 Procedures and Standards

Only certified people are to carry out charging and changing of batteries and the charging procedures and standards are to be displayed at all times.

2.2 Charging Racks

2.2.1 Operations

For the charging of cap lamp assemblies, it is recommended that the quantity of units to be charged does not exceed the maximum charger capacity of 204 units.

2.2.2 Equipment Changes

It is recommended that the existing wooded charging racks be phased out as these can pose a physical hazard due to a wooden rack burning. This could be caused by loose connections or a poorly maintained resistor spring.

2.3 Miners Cap Lamp

2.3.1 Operations and Standards

- High risk areas and consequences in which users need to be made aware of and addressed are:
 - Lock Pin tampering
 - Switch Knob tampering
 - Lock Barrel tampering
 - Poor maintenance

2.4 Loco Light

2.4.1 Statutory Equipment

It is recommended that the manufacturer and supplier of the **Portable Loco Light** has tested this equipment to ensure compliance with the Mine Health and Safety Act, 21 of 1996 as well as the IEC Standard.

It is also recommended that Maintenance and Trouble Shooting Notes be compiled for this equipment.

2.5 Tox Alarm and Flam Alarm

2.5.1 Training (In general)

It is recommended that a training programme for the users of this equipment should address both operational and maintenance requirements and should focus on the following:

- Carry out supplier's recommended maintenance and inspection procedures.

- Use of OEM parts
- Regular retraining of users
- Daily checks on equipment as per OEM instructions

2.6 Standby Batteries

2.6.1 Maintenance Programme

Proper battery maintenance procedures and instructions must be followed and the following actions should be considered:

- Transportation and storage to comply with OSH act and Lead regulations.
- FNB to include their Installation and Maintenance and Safety in each delivery.

SECTION 3

ASSESSMENT METHODOLOGY

SECTION 3


RISK ASSESSMENT METHODOLOGY

Details of the Risk Assessment methodology have been included as part of this report:

- For future reference purposes, should someone want to know exactly how and what was done for the Risk Assessment;
- To show the extent to which FNB has systematically and thoroughly reviewed the equipment. This assures that FNB has taken all “reasonably practicable steps” to identify the proper use and maintenance of the equipment available and used on the mines.

3.1 RISK ASSESSMENTS

Legislation requires that Risk Assessments be performed. This implies that organisations should identify the relevant areas of risk, quantify those risks, prioritise them, determine those, which are deemed excessive, apply suitable treatment and controls, review the resultant risk profile and repeat the process. The success of such an approach is dependent on the application of these principles. The techniques used are important, but ensuring that the process is followed to completion is the key to success. This can be demonstrated as follows:



The framework that organisations implement and the ongoing measurement of the continued application thereof should thus minimise business interruption, provide factual quantified information which can be used for decisions regarding risk management, contribute to risk reduction and provide opportunities for cost savings.

3.2 PRE ASSESSMENT REVIEW

To ensure that all possible available information was considered as part of this assessment, the following reviews were conducted.

3.2.1 STATUTORY REVIEW

The Mine Health and Safety Act, 21 of 1996 was reviewed and used in the assessment in order that relevant legal requirements were brought to the attention of the Risk Assessment team and discussed for applicability.

3.3 “WHAT IF” METHODOLOGY

The “What If” assessment technique is an effective high-level hazard identification tool. It is a thorough, systematic, team oriented analytical technique.

The “What If” is a system-oriented technique, which allows the examination of complete operations (systems) or sub operations (sub-systems). As with any Risk Assessment, the selection of, and participation by the team is vital to the outcome of the assessment.

The objective of any Risk Assessment is to methodically analyse systems and components thereof to identify potential hazards and to record them. This is an ongoing process and it is recommended that FNB do not view this What If as a “once off” assessment, as conditions (people, equipment and methods) are continuously changing.

3.3.1 ASSESSMENT PROCESS

Prior to the assessment Eugene Pininski held a familiarisation presentation with the team members, to explain the process to be used. This gave the team members a good understanding of the What If process, how hazards are identified and thereafter the risks assessed and classified.

3.3.2 SWIFT PROCESS

The Structured What If technique was used for the following reasons;

- The Structured What If Technique is good for analysing closely related equipment operations and identifying potential hazards.

- The Structured What If technique allows both equipment and sub components to be assessed.

For each equipment and sub component a design intent was defined. Section 6 details the design intent. A brainstorm session was then conducted for each equipment, to identify possible hazards. These were recorded and used as a guide, and reminder, for the duration of the assessment.

The Structured “What If” technique relies on structured questioning to determine potential risks. The questions are prompted by applying the What If question categories in turn, (see section 3.3.3 below) to each design intent, for all the equipment considered. This is a lengthy process, however if used correctly, it dramatically reduces the probability of “missing” hazards. Each hazard identified is comprehensively evaluated for causes, consequences, safeguards, risk ranking, recommendations and is recorded. The results of these records are contained in Sections 5 to 12 of this Report.

3.3.3 “WHAT IF” STRUCTURED QUESTION CATEGORIES

The Structured “What If” question categories, which were used as a basis for each equipment and design intent is as follows:

MATERIAL PROBLEMS - (MP)
Hazardous materials Availability of material Use of material Suitability of material Raw material
EXTERNAL EFFECTS OR INFLUENCES - (EE/I)
Labour unrest Civil disturbance Accidents Damage to equipment Natural causes Statutory requirements

OPERATING ERRORS AND OTHER HUMAN FACTORS - (OE & HF)

Human errors
Job characteristics
Communication
Ergonomics
Safety issues
Environmental factors
Quality factors

EQUIPMENT OR INSTRUMENTATION MALFUNCTION - (E/IM)

Failure modes
Failure causes
Failure characteristics
Operator actions/non actions

PHYSICAL HAZARDS - (PH)

Slips
Tripping
Falling
Incline
Moving machinery
Height/space restrictions
Electricity
Clearances
Guarding
Fire
Dust

UTILITY FAILURES - (UF)

Service failure
Compressed air
Water
Electrical power
Gas supply
Communication
Ventilation
Fuel storage
Waste disposal
Fire
Gas storage

ANALYTICAL OR SAMPLING ERRORS (ASE)
Procedures Wrong type
PROCESS UPSETS OF UNSPECIFIED ORIGIN (PUUO)
As specified
INTEGRITY FAILURE OR LOSS OF CONTAINMENT (IFLOC)
Pressure vessels ruptured Process spillage
EMERGENCY OPERATIONS (EO)
As specified
ENVIRONMENTAL RELEASE (ER)
Pollution of ground Pollution of water Pollution of air

3.4 RISK RANKING METHODOLOGY

In order that a suitable “Level of Importance” is attached to each hazard, the hazard is allocated a “Risk Priority”. The risk priority is a combination of the consequence (severity) of the event and the frequency or probability of the event (normally estimated).

3.4.1 Consequences/Severity of event

CODE	DESCRIPTION
A	Multiple Fatality and/or > R10M
B	Fatality and/or R1-10 Million
C	Reportable Injury and/or R 0.1-1 Million
D	Injury and/ or R 0.01-0.1 Million

E	Minor Injury and/or < R10 000
----------	-------------------------------

3.4.2 Frequency/Probability of Event

CODE	DESCRIPTION
1	Once per week
2	Once per month
3	Once per year
4	Once in 10 years
5	Once in 100 years

3.4.3 Risk Priority Ranking

CONSEQUENCE						
F R E Q		A	B	C	D	E
	1	1	2	3	4	5
	2	2	3	4	5	6
	3	3	4	5	6	7
	4	4	5	6	7	8
	5	5	6	7	8	9

The 9 priority codes as indicated above can further be categorised into 3 levels of criticality.

HIGHLY CRITICAL: Task/recommendation to be implemented without delay. (Priority Code 1, 2, 3).

CRITICAL: Hazards with this criticality are significant and these recommendations should be implemented as soon as practicable. (Priority Codes 4, 5, 6).

LESS CRITICAL: No major injury or financial hazards. Recommendation to be addressed when time/resources permit (Priority Codes 7, 8, 9).

3.4 RECOMMENDATION TYPE

In order that the recommendations made, are properly summarised in the report and for further follow up action, each

recommendation was categorised into one of the following recommendation types;

CODE	DESCRIPTION
A	Specify acceptance criteria
D	Design Change (capex required)
E	Engineering Change (no capex)
I	Inspection Required
L	Legal Query
M	Update Operations manual
O	Operator Training
OT	Operator and Technical Training
P	Procedure Required
Q	Equipment Change Required
R	Research Required
RA	Conduct or update Risk Assessment
S	Standard Required
T	Technical Training
W	Software Change Required

3.5 “WHAT IF” IDENTIFICATION CODES

- i Systems or Operations were allocated “S” numbers for example;

S01 = Motive power

S02 = Chargers

These are detailed in Section 5 of this report.

- ii System or Designs intents were allocated “I” numbers. The “I” number was re-started at 1 for each new system, for example:

S01 I01 Provide power to mobile equipment

S02 I01 To charge motive power batteries

These are detailed in Section 6 of this report.

- iii Each recommendation has been allocated a unique “R” number e.g. “R001”. The complete list of recommendations are contained in sections 8, 9, 10 of this report.

SECTION 4

RISK ASSESSMENT DATA ANALYSIS

MOTIVE POWER AND CHARGERS

4.0 MOTIVE POWER AND CHARGERS

RISK ASSESSMENT DATA ANALYSIS

In this section the data contained in the Risk Assessment database has been extracted and summarised in various formats for graphical display.

GRAPH 1 - RISK PROFILE

This graph shows the total technical high level risk profile for all the issues assessed. The intent of such a profile is that FNB establishes an acceptable level of risk and then addresses all the hazards, which lie above this level down to acceptable levels. The diagram in section 3.1 depicts the Risk Management process to follow, once such a profile has been determined.

The immediate goal should be to address the top 20 to 30% of the risks identified as per the Pareto 20:80 principle.

As can be seen from this profile, the three highest risks identified are for:

- Explosions due to open flames
- Explosions due to short circuits
- Explosions due to tracking

The major focus concerning these hazards should be that the users of this equipment follow the supplier's installation and maintenance procedures and that the batteries must be covered.

GRAPH 2 - SUMMARY OF RISKS BY "WHAT IF" CATEGORY

This graph shows that the majority of hazards identified were related to operator errors or human factors (50%) as well as physical hazards (33%) in the operation and use of the equipment. This implies that the major focus must be on properly managing or engineering out the hazards that users are exposed to and ensuring that users of equipment utilise it correctly through procedures, training and task observations.

GRAPH 3 - SUMMARY OF RECOMMENDATIONS BY TYPE

This graph indicates that the majority of recommendations are related to Standards and Procedures Required in order to ensure that the supplier's safety and installation procedures are followed. There is also the need to update Operations Manuals and to ensure that the appropriate Maintenance Manuals are current.

GRAPH 4 - SUMMARY OF RECOMMENDATIONS BY RESPONSIBILITY


This last graph shows the recommendation responsibilities for the different managerial functions within FNB and also an indication of customer responsibilities.

The majority of responsibilities are with the customer, being the users of the equipment. There are also tasks allocated to the Technical Service Manager, which ties up with the issue that FNB needs to combine all safety rules in one paragraph in the Installation, Maintenance and Safety instructions in order for users to be made aware of hazards which could arise.

Graph 1


First National Battery - Risk Profile

Motive Power and Chargers




Graph 2

**First National Battery - Summary of Hazards by "What If"
Category**
Motive Power and Chargers




Graph 3



Graph 4

First National Battery - Recommendations Responsibility Graph
Motive Power and Chargers



SECTION 4

RISK ASSESSMENT WORKSHEET REPORT

MOTIVE POWER AND CHARGERS

First National Battery

17 August 2001

Motive Power and Chargers

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS

Risk Assessment Worksheet Report

S01 Motive Power

I01 Provide power to mobile equipment

Hazard What if the take-off connection plug is connected in reverse

Category Freq 3 Sev D
EEI Risk Priority 6

Cause Bad workmanship

Consq Damage to forklift

S/guard Final quality checks

Who Type

Who Type

Hazard What if burn on cells are changed

Category Freq 3 Sev B
PH Risk Priority 4

Cause Heat applied to melt the welded connection off the terminal

Consq Explosion, injuries, fatalities, damage to equipment

S/guard Procedures in place

Only manufacturer replaces cell. If individual cell are sold then a safety sticker to be attached.

R001

Who Type
QAM S

Who Type

Hazard What if charging procedures are not followed correctly when battery is left in vehicle

Category Freq 2 Sev B
OE&HF Risk Priority 3

Cause Lack of procedures and training

Consq Overheating, explosions, damage to product, injuries.

S/guard Current charging procedure and instructions and PPE's,

Charging procedure and instructions must be displayed at all times and followed.

R002

Who Type
MM P

Only certified people to carry out charging and changing of batteries when there is more than one battery

R003

Who Type
CUS S

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report

<p>Hazard What if cells and acid are transported and/or stored</p> <p>Cause Incorrect material handling</p> <p>Consq Acid spillage, short circuit, toppling over</p> <p>S/guard Special containers for acid. PPE's, strapping in place and uprights</p> <p>Transportation and storage to comply with OSH act and Lead regulations (Refer to Package and Transport and Storage) also refer to installation and maintenance procedures</p> <p>R004</p> <p>When transporting cells ensure that insulators are fitted to terminals</p> <p>R005</p>	<p>Category PH</p> <p>Freq 2</p> <p>Sev 5</p> <p>D</p> <p>Who EM</p> <p>Type S</p>	<p>Frequency 2</p> <p>Risk Priority 5</p>	<p>Who EM</p> <p>Type S</p>
<p>Hazard What if acid is spilled</p> <p>Cause Battery is mishandled, dropped, bumped, collisions or exploding</p> <p>Consq Injuries, damaged equipment due to corrosion</p> <p>S/guard Alkaline neutralizer to be used on spillage e.g.. hydrated lime</p> <p>Follow the battery maintenance instruction and procedures in case of people involved</p> <p>R006</p>	<p>Category OE&HF</p> <p>Freq 3</p> <p>Sev 6</p> <p>D</p> <p>Who CUS</p> <p>Type MP</p>	<p>Frequency 3</p> <p>Risk Priority 6</p>	<p>Who CUS</p> <p>Type MP</p>
<p>Hazard What if there is a battery abuse-maintenance</p> <p>Cause Poor maintenance and improper usage</p> <p>Consq Premature failure</p> <p>S/guard Follow maintenance and instruction manual</p> <p>Follow the battery maintenance instruction and procedures</p> <p>R007</p>	<p>Category OE&HF</p> <p>Freq 2</p> <p>Sev 4</p> <p>C</p> <p>Who CUS</p> <p>Type MP</p>	<p>Frequency 2</p> <p>Risk Priority 4</p>	<p>Who CUS</p> <p>Type MP</p>
<p>Hazard What if there is an explosion due to chafing of positive and negative take-off cables on steel tank.</p> <p>Cause Cable insufficiently protected</p> <p>Consq Short causing a fire or explosion, fatalities ,injuries and equipment loss</p> <p>S/guard NIL</p> <p>Ensure pratty compression glands are fitted and suppliers of tank to be instructed to change design of entry for cable</p> <p>R008</p> <p>Bulletin to be sent out to customers and end users</p> <p>R009</p>	<p>Category PH</p> <p>Freq 3</p> <p>Sev 4</p> <p>B</p> <p>Who MM</p> <p>Type E</p>	<p>Frequency 3</p> <p>Risk Priority 4</p>	<p>Who MM</p> <p>Type E</p> <p>Who MD</p> <p>Type P</p>

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report

<p>Hazard What if there is an explosion due to loose connections</p> <p>Cause Incorrect torque and vibration</p> <p>Consq Explosion of battery causing fatalities and injury and equip damage</p> <p>S/guard Ensure torque setting are met and regular checking</p> <p>Add to installation and maintenance procedures that Torque to be checked Regularly</p> <p>R010</p>	<p>Category OE&HF</p> <p>Freq 2</p> <p>Sev B</p> <p>Risk Priority 3</p>	<p>Who TS</p> <p>Type M</p>
<p>Who Type</p>		
<p>Hazard What if there is an explosion due to tracking</p> <p>Cause Overfilling when topping up</p> <p>Consq Explosion of battery causing fatalities and injury and equipment damage</p> <p>S/guard Keep battery cell lids clean and dry</p> <p>Follow suppliers installation and maintenance procedures</p> <p>R011</p>	<p>Category PH</p> <p>Freq 1</p> <p>Sev B</p> <p>Risk Priority 2</p>	<p>Who CUS</p> <p>Type M</p>
<p>Who Type</p>		
<p>Hazard What if there is an explosion due to short circuit due to external sources, metal on connectors, terminals</p> <p>Cause Material falling on batteries</p> <p>Consq Explosion of battery causing fatalities and injury and equipment damage</p> <p>S/guard Batteries to be covered at all times while in operation.</p> <p>Procedures to be followed as stated in safety rules. Include in safety rules that batteries must be covered.</p> <p>R012</p> <p>Make sure that insulators are fitted to all terminals and are kept in place at all times.</p> <p>R013</p>	<p>Category OE&HF</p> <p>Freq 1</p> <p>Sev B</p> <p>Risk Priority 2</p>	<p>Who TS</p> <p>Type P</p>
<p>Who Type</p>		
<p>Hazard What if there is an explosion due to an open flame, welding,</p> <p>Cause Flame ignites hydrogen</p> <p>Consq Explosion causing a fatality, spillage of acid, injury, material damage,</p> <p>S/guard Good ventilation, procedures in place to prevent smoking ,open flames, electrical shorts or sparks, switch off circuit breaker before disconnecting plug from battery.</p> <p>Safety rules as laid out in Installation and Maint instruction to be followed.</p> <p>R014</p> <p>Installation and Maintenance and Safety instructions to be included in each delivery. FNB to combine all safety rules in one paragraph in Installation and Maintenance and Safety instructions.</p> <p>R015</p>	<p>Category EEI</p> <p>Freq 2</p> <p>Sev A</p> <p>Risk Priority 2</p>	<p>Who CUS</p> <p>Type P</p>
<p>Who Type</p>		
<p>Who Type</p>		

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report

S02 **Chargers**

I01 **To charge motive power batteries**

Hazard What if incorrect size charger is used

Category **Freq** 3 **Sev** D
OE&HF **Risk Priority** 6

Cause Ignorance, human error

Consq Battery may over/under charge. Undercharge can cause loss of production. Overcharge can cause damage to battery.

S/guard Nil

Use different take-off connector plugs for different batteries

R016

Who **Type**
CUS S

Who **Type**

End of Report

SECTION 4

WORKSHEET REPORT (SORTED BY WORK AREA AND RISK PRIORITY)

MOTIVE POWER AND CHARGERS

First National Battery

17 August 2001

Motive Power and Chargers

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS Risk Assessment Worksheet Report sorted by Work Area and Risk Priority

S01 Motive Power

I01 Provide power to mobile equipment

Hazard What if there is an explosion due to tracking

Category Freq 1 Sev B
 PH Risk Priority 2

Cause Overfilling when topping up

Consq Explosion of battery causing fatalities and injury and equipment damage

S/guard Keep battery cell lids clean and dry

Follow suppliers installation and maintenance procedures

Who Type
 CUS M

R011

Who Type

Hazard What if there is an explosion due to short circuit due to external sources, metal on connectors, terminals

Category Freq 1 Sev B
 OE&HF Risk Priority 2

Cause Material falling on batteries

Consq Explosion of battery causing fatalities and injury and equipment damage

S/guard Batteries to be covered at all times while in operation.

Procedures to be followed as stated in safety rules. Include in safety rules that batteries must be covered.

Who Type
 TS P

R012

Make sure that insulators are fitted to all terminals and are kept in place at all times.

Who Type
 Who Type
 QAM M

R013

Hazard What if there is an explosion due to an open flame, welding,

Category Freq 2 Sev A
 EEI Risk Priority 2

Cause Flame ignites hydrogen

Consq Explosion causing a fatality, spillage of acid, injury, material damage,

S/guard Good ventilation, procedures in place to prevent smoking ,open flames, electrical shorts or sparks, switch off circuit breaker

Safety rules as laid out in Installation and Maint instruction to be followed.

Who Type
 CUS P

R014

Installation and Maintenance and Safety instructions to be included in each delivery. FNB to combine all safety rules in one paragraph in Installation and Maintenance and Safety instructions.

Who Type
 Who Type
 TSM

R015

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report sorted by Work Area and Risk Priority

I01 Provide power to mobile equipment

Hazard What if charging procedures are not followed correctly when battery is left in vehicle **Category** OE&HF **Freq** 2 **Sev** B **B**
Risk Priority 3

Cause Lack of procedures and training

Consq Overheating, explosions, damage to product, injuries.

S/guard Current charging procedure and instructions and PPE's,

Charging procedure and instructions must be displayed at all times and followed.

R002

Who MM **Type** P

Only certified people to carry out charging and changing of batteries when there is more than one battery

R003

Who Who
Type Type
 CUS S

Hazard What if there is an explosion due to loose connections

Category OE&HF **Freq** 2 **Sev** B **B**
Risk Priority 3

Cause Incorrect torque and vibration

Consq Explosion of battery causing fatalities and injury and equip damage

S/guard Ensure torque setting are met and regular checking

Add to installation and maintenance procedures that Torque to be checked Regularly

R010

Who TS **Type** M

Who **Type**

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report sorted by Work Area and Risk Priority

I01 Provide power to mobile equipment

Hazard What if burn on cells are changed	Category PH	Freq 3	Sev B	B
		Risk Priority 4		
Cause Heat applied to melt the welded connection off the terminal				
Consq Explosion, injuries, fatalities,damage to equipment				
S/guard Procedures in place				
Only manufacturer replaces cell. If individual cell are sold then a safety sticker to be attached.				Who Type
R001				QAM S

Who **Type**

Hazard What if there is a battery abuse-maintenance	Category OE&HF	Freq 2	Sev C	C
		Risk Priority 4		
Cause Poor maintenance and improper usage				
Consq Premature failure				
S/guard Follow maintenance and instruction manual				
Follow the battery maintenance instruction and procedures				Who Type
R007				CUS MP

Who **Type**

Hazard What if there is an explosion due to chafing of positive and negative take-off cables on steel tank.	Category PH	Freq 3	Sev B	B
		Risk Priority 4		
Cause Cable insufficiently protected				
Consq Short causing a fire or explosion, fatalities ,injuries and equipment loss				
S/guard NIL				
Ensure pratty compression glands are fitted and suppliers of tank to be instructed to change design of entry for cable				Who Type
R008				MM E

Bulletin to be sent out to customers and end users				Who Type
R009				Who Type
				MD P

I01 Provide power to mobile equipment

Hazard What if cells and acid are transported and/or stored	Category PH	Freq 2	Sev D	D
		Risk Priority 5		
Cause Incorrect material handling				
Consq Acid spillage, short circuit, toppling over				
S/guard Special containers for acid. PPE's, strapping in place and uprights				
Transportation and storage to comply with OSH act and Lead regulations (Refer to Package and Transport and Storage) also refer to installation and maintenance procedures				Who Type
R004				

EM

When transporting cells ensure that insulators are fitted to terminals
R005

S

Who	Type
Who	Type
EM	S

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report sorted by Work Area and Risk Priority

I01 Provide power to mobile equipment

Hazard What if the take-off connection plug is connected in reverse

Category **Freq** **3** **Sev** **D**
EEI **Risk Priority 6**

Cause Bad workmanship

Consq Damage to forklift

S/guard Final quality checks

Who **Type**

Who **Type**

Hazard What if acid is spilled

Category **Freq** **3** **Sev** **D**
OE&HF **Risk Priority 6**

Cause Battery is mishandled, dropped, bumped, collisions or exploding

Consq Injuries, damaged equipment due to corrosion

S/guard Alkaline neutralizer to be used on spillage e.g.. hydrated lime

Follow the battery maintenance instruction and procedures in case of people involved

R006

Who **Type**
CUS **MP**

Who **Type**

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report sorted by Work Area and Risk Priority

S02 Chargers

I01 To charge motive power batteries

Hazard What if incorrect size charger is used

Category **Freq** 3 **Sev** D
OE&HF **Risk Priority** 6

Cause Ignorance, human error

Consq Battery may over/under charge. Undercharge can cause loss of production. Overcharge can cause damage to battery.

S/guard Nil

Use different take-off connector plugs for different batteries

R016

Who **Type**
CUS S

Who **Type**

End of Report

SECTION 5

RISK ASSESSMENT DATA ANALYSIS

CHARGING RACKS

5.0 CHARGING RACKS

RISK ASSESSMENT DATA ANALYSIS

In this section the data contained in the Risk Assessment database has been extracted and summarised in various formats for graphical display.

GRAPH 1 - RISK PROFILE

As can be seen from this profile, there are four high risks identified for:

- Chargers being tampered with
- Loose connections
- Poor maintenance on chargers
- Fire on wooden racks

The major focus concerning these hazards should be that the users of this equipment follow the supplier's installation and maintenance procedures and that it is recommended that wooden racks be phased out and replaced with metal racks.

GRAPH 2 - SUMMARY OF RISKS BY "WHAT IF" CATEGORY

Here there was a single hazard of significance which was related to operator errors or human factors (7/10). Physical hazards in the operation, use and maintenance of the equipment, as well as external effects due to poor ventilation was also identified. Also, in order to reduce the risk of equipment malfunction, qualified personnel only should work on the equipment.

GRAPH 3 - SUMMARY OF RECOMMENDATIONS BY TYPE


This graph indicates that the majority of recommendations are related to user standards required to ensure that the supplier's safety and installation procedures are followed. There is also the need to update Operations Manuals and to ensure that the appropriate Maintenance Programmes are in place to ensure that procedures are followed by users.

GRAPH 4 - SUMMARY OF RECOMMENDATIONS BY RESPONSIBILITY

This graph shows the recommendation responsibilities for the different managerial functions within FNB and also an indication of customer responsibilities.

The majority of responsibilities are with the customer, being the users of the equipment. There are also tasks allocated to the Technical Service Manager, which ties up with the issue that FNB needs to ensure that the Miners Cap Lamp Maintenance and Troubleshooting Notes are modified.


Graph 1



Graph 2

First National Battery - Summary of Hazards by "What If" Category


Charging Racks



Graph 3

First National Battery - Recommendations by Type


Charging Racks



Graph 4

First National Battery - Recommendations Responsibility Graph

Charging Racks



SECTION 5

RISK ASSESSMENT WORKSHEET REPORT

CHARGING RACKS

First National Battery

17 August 2001

Charging Racks

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS

Risk Assessment Worksheet Report

S01 **Charging Racks**

I01 **To recharge cap lamp assemblies**

Hazard What if chargers are tampered with

Category **Freq** 3 **Sev** B
OE&HF **Risk Priority** 4

Cause Insufficient charge amp capacity

Consq Over and under charging of lamps, conductors running hot and battery lifespan diminished

S/guard NIL

Leave charger at factory set point

R001

Who **Type**
CUS S

Who **Type**

Hazard What if there is incorrect mains supply voltage

Category **Freq** 4 **Sev** D
OE&HF **Risk Priority** 7

Cause Operator fails to observe input supply specifications

Consq Under charging, damage to charger

S/guard Specification plate fitted to charger

Ensure correct connection to specified electrical supply

R002

Who **Type**
CUS P

Who **Type**

Hazard What if the quantity of units exceeds the charger capacity

Category **Freq** 3 **Sev** E
OE&HF **Risk Priority** 7

Cause Insufficient number of chargers for the racks

Consq Insufficient charging rate resulting in undercharged lamps

S/guard NIL

Must have one charger for max 204 charging points

R003

Who **Type**
CUS S

Who **Type**

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report

Hazard	What if incorrect conductor size , length and connectors are used	Category	Freq	4	Sev	D
		OE&HF	Risk Priority	7		
Cause	Cables replaced by incompetent people					
Consq	Undercharging of batteries, conductors running hot, hot connections					
S/guard	Procedure in place					
	Use qualified personnel to do installations and maintenance				Who	Type
R004					CUS	MP
					Who	Type
Hazard	What if there is incorrect polarity	Category	Freq	3	Sev	D
		E&IM	Risk Priority	6		
Cause	Incorrect connection					
Consq	Reverse polarity battery charge. Battery damage					
S/guard	Bus bars clearly marked					
	Charges to be fitted on top the rack. Connected by qualified personnel				Who	Type
R005					CUS	T
					Who	Type
Hazard	What if there are high room temperatures exceeding manufacturers specifications	Category	Freq	4	Sev	D
		EEI	Risk Priority	7		
Cause	Poor ventilation and construction					
Consq	Premature equipment failure					
S/guard	Procedures available in Miners Cap Lamp Maintenance and Troubleshooting Notes					
	Good ventilation				Who	Type
R006					CUS	Q
					Who	Type
Hazard	What if there are loose connections	Category	Freq	3	Sev	B
		OE&HF	Risk Priority	4		
Cause	Poor maintenance					
Consq	Poor charging rate, possible fire (wooden racks)					
S/guard	Procedures available in Miners Cap Lamp Maintenance and Troubleshooting Notes					
	Maint procedures for stainless steel racking to be incorporated in Miners Cap Lamp Maintenance and Troubleshooting Notes				Who	Type
R007					TS	M
					Who	Type

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report

Hazard What if poor maintenance is carried out **Category** OE&HF **Freq** 2 **Sev** D **D**
Risk Priority 5

Cause Poor supervision

Consq Cap lamp failures, loss of production, possible fires(wooden racks)

S/guard Procedures available in Miners Cap Lamp Maintenance and Troubleshooting Notes

Ensure maintenance procedures are followed **Who** **Type**
R008 CUS MP

Who **Type**

Hazard Can there be a fire on the wooden rack **Category** PH **Freq** 4 **Sev** B **B**
Risk Priority 5

Cause Loose connections, poorly maintained resistor spring

Consq Fire, injuries, equipment damage, production loss

S/guard Procedures available in Miners Cap Lamp Maintenance and Troubleshooting Notes

Phase out wooden racks **Who** **Type**
R009 CUS Q

Who **Type**

Hazard What if the cap lamp is not placed on charge correctly on racks **Category** OE&HF **Freq** 2 **Sev** E **E**
Risk Priority 6

Cause Insufficient training, hastiness;

Consq Failure to recharge

S/guard Physical check which gives a visual indication via instrumentation.

Procedures to be added to Lamp Room Routine **Who** **Type**
R010 TS M

Who **Type**

End of Report

SECTION 5

WORKSHEET REPORT (SORTED BY WORK AREA AND RISK PRIORITY)

CHARGING RACKS

First National Battery

17 August 2001

Charging Racks

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS **Risk Assessment Worksheet Report sorted by Work Area and Risk Priority**

S01 **Charging Racks**

I01 **To recharge cap lamp assemblies**

Hazard **What if chargers are tampered with**

Category **Freq** **3** **Sev** **B**
OE&HF **Risk Priority4**

Cause Insufficient charge amp capacity

Consq Over and under charging of lamps, conductors running hot and battery lifespan diminished

S/guard NIL

Leave charger at factory set point

R001

Who **Typ**
CUS **S**

Who **Typ**

Hazard **What if there are loose connections**

Category **Freq** **3** **Sev** **B**
OE&HF **Risk Priority4**

Cause Poor maintenance

Consq Poor charging rate, possible fire (wooden racks)

S/guard Procedures available in Miners Cap Lamp Maintenance and Troubleshooting Notes

Maint procedures for stainless steel racking to be incorporated in Miners Cap Lamp Maintenance and

R007 Troubleshooting Notes

Who **Typ**

TS **M**

Who **Typ**

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report sorted by Work Area and Risk Priority

I01 To recharge cap lamp assemblies

Hazard What if poor maintenance is carried out

Category OE&HF **Freq** 2 **Sev** D
Risk Priority 5

Cause Poor supervision

Consq Cap lamp failures, loss of production, possible fires(wooden racks)

S/guard Procedures available in Miners Cap Lamp Maintenance and Troubleshooting Notes

Ensure maintenance procedures are followed

R008

Who CUS **Typ** MF

Who Typ

Hazard Can there be a fire on the wooden rack

Category PH **Freq** 4 **Sev** B
Risk Priority 5

Cause Loose connections, poorly maintained resistor spring

Consq Fire, injuries, equipment damage, production loss

S/guard Procedures available in Miners Cap Lamp Maintenance and Troubleshooting Notes

Phase out wooden racks

R009

Who CUS **Typ** C

Who Typ

I01 To recharge cap lamp assemblies

Hazard What if there is incorrect polarity

Category E&IM **Freq** 3 **Sev** D
Risk Priority 6

Cause Incorrect connection

Consq Reverse polarity battery charge. Battery damage

S/guard Bus bars clearly marked

Charges to be fitted on top the rack. Connected by qualified personnel

R005

Who CUS **Typ** T

Who Typ

Hazard What if the cap lamp is not placed on charge correctly on racks

Category OE&HF **Freq** 2 **Sev** E
Risk Priority 6

Cause Insufficient training, hastiness;

Consq Failure to recharge

S/guard Physical check which gives a visual indication via instrumentation.

Procedures to be added to Lamp Room Routine

R010

Who TS **Typ** M

Who Typ

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report sorted by Work Area and Risk Priority

I01 To recharge cap lamp assemblies

Hazard What if there is incorrect mains supply voltage	Category OE&HF	Freq 4	Sev D	D
		Risk Priority 7		
Cause Operator fails to observe input supply specifications				
Consq Under charging, damage to charger				
S/guard Specification plate fitted to charger				
	Ensure correct connection to specified electrical supply			Who Typ
R002				CUS F

Who Typ

Hazard What if the quantity of units exceeds the charger capacity	Category OE&HF	Freq 3	Sev E	E
		Risk Priority 7		
Cause Insufficient number of chargers for the racks				
Consq Insufficient charging rate resulting in undercharged lamps				
S/guard NIL				
	Must have one charger for max 204 charging points			Who Typ
R003				CUS S

Who Typ

Hazard What if incorrect conductor size , length and connectors are used	Category OE&HF	Freq 4	Sev D	D
		Risk Priority 7		
Cause Cables replaced by incompetent people				
Consq Undercharging of batteries, conductors running hot, hot connections				
S/guard Procedure in place				
	Use qualified personnel to do installations and maintenance			Who Typ
R004				CUS MF

Who Typ

Hazard What if there are high room temperatures exceeding manufacturers specifications	Category EEI	Freq 4	Sev D	D
		Risk Priority 7		
Cause Poor ventilation and construction				
Consq Premature equipment failure				
S/guard Procedures available in Miners Cap Lamp Maintenance and Troubleshooting Notes				
	Good ventilation			Who Typ
R006				CUS C

Who Typ

End of Report

SECTION 6

RISK ASSESSMENT DATA ANALYSIS

UNDERGROUND ILLUMINATION

6.0 UNDERGROUND ILLUMINATION

RISK ASSESSMENT DATA ANALYSIS

(Miners Cap Lamp, Leisure Lamp, Loco light, CM remote adaptor)

In this section the data contained in the Risk Assessment database has been extracted and summarised in various formats for graphical display.

GRAPH 1 - RISK PROFILE

Four of the high risks are identified as follows:

- Poor maintenance done on Cap Lamps
- Lock pin tampered with on Cap Lamps
- Inline fuse blows
- Broken exit cover, retaining clip and screws, on Cap Lamps

The major focus concerning these hazards should be that the users are aware of the hazards and dangers and also to follow the supplier's installation and maintenance procedures. Furthermore, trained and certified personnel are to work on the equipment and to use OEM equipment and supplies.

GRAPH 2 - SUMMARY OF RISKS BY "WHAT IF" CATEGORY

Three hazards, which are of significance, are related to operator errors or human factors (8/30) Physical hazards in the operation, use and maintenance of the equipment (8/30) as well as Material problems due to the various components, which may require proper maintenance. Similarly, in order to reduce the risk of equipment malfunction, qualified personnel only should work on the equipment and to report any defects after a shift.

GRAPH 3 - SUMMARY OF RECOMMENDATIONS BY TYPE


This graph indicates that the majority of recommendations are related to user standards required to ensure that the supplier's safety and installation procedures are followed. There is also the need to update Operations Manuals and to ensure that the appropriate Maintenance Programmes are in place to ensure that users follow procedures.

GRAPH 4 - SUMMARY OF RECOMMENDATIONS BY RESPONSIBILITY

The majority of responsibilities are with the customer, being the users of the equipment. There are also tasks allocated to the Technical Service Manager, which ties up with the issue that FNB needs to ensure that the Miners Cap Lamp Maintenance and Troubleshooting Notes are modified.


Furthermore, MSA need to ensure that Maintenance and Trouble Shooting Notes for their equipment is compiled and available to the users.

Graph 1



Graph 2


First National Battery - Summary of Hazards By "What If" Category Underground Illumination



Graph 3


First National Battery - Recommendations by Type

Underground Illumination



Graph 4

**First National Battery - Recommendations Responsibility Graph
Underground Illumination**



SECTION 6

SUB SYSTEM/OPERATION REPORT

UNDERGROUND ILLUMINATION

First National Battery

17 August 2001

Underground Illumination

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS

Sub System Description Report

Sub System No. and Description

S01	Miners Cap Lamps
S02	Leisure Lamp
S03	Loco Light
S04	CM remote adaptor

End of Report

SECTION 6

SUB SYSTEM AND DESIGN INTENT REPORT

UNDERGROUND ILLUMINATION

First National Battery

17 August 2001

Underground Illumination

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS

Sub System and Design Intent Report

Sub System No. and Design Intent Description

S01 **Miners Cap Lamps**

I01 Illumination of personal work area

S02 **Leisure Lamp**

I01 Provide illumination for leisure purposes

S03 **Loco Light**

I01 Provide illumination for underground tramming vehicles

S04 **CM remote adaptor**

I01 Source of power for continuous miner remote control

End of Report

SECTION 6

RISK ASSESSMENT WORKSHEET REPORT

UNDERGROUND ILLUMINATION

First National Battery

17 August 2001

Underground Illumination

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS

Risk Assessment Worksheet Report

S01 Miners Cap Lamps

I01 Illumination of personal work area

Hazard What if lock pin is tampered with

Category Freq 1 Sev A
OE&HF Risk Priority1

Cause Illegal use of electricity supply

Conseq Underground fires, explosion of flammable gas, fatalities and injuries, damage to equipment

S/guard Sealing wax to prevent tampering. Special tool required to remove lock pin

R001 Employees to be made aware of dangers and consequences

Who Type
CUS S

R002 Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes

Who Type
TS M

Hazard What if Lock Barrel is tampered with

Category Freq 4 Sev A
OE&HF Risk Priority4

Cause Illegal use of electricity supply

Conseq Underground fires, explosion of flammable gas, fatalities and injuries, damage to equipment

S/guard Charging key must be used

R003 Employees to be made aware of dangers and consequences

Who Type
CUS S

R004 Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes

Who Type
TS M

Hazard What if Switch Knob is tampered with

Category Freq 4 Sev A
OE&HF Risk Priority4

Cause Illegal use of electricity supply

Conseq Underground fires, explosion of flammable gas, fatalities and injuries, damage to equipment

S/guard Switch knob cannot be removed from outside

R005 Employees to be made aware of dangers and consequences

Who Type
CUS S

R006 Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes

Who Type
TS M

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report

Hazard What if the bulb fails	Category MP	Freq 2 Risk Priority 4	Sev 4	C
Cause Limited life				
Consq Worker has no light and can be injured				
S/guard NIL				
R007 Worker not allowed to be on his own			Who CUS	Type S
R008 Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes			Who TS	Type M
Hazard What if there is a broken lens ring and head piece molding	Category PH	Freq 3 Risk Priority 5	Sev 5	C
Cause Lens ring and head pieces knocked hard and abused				
Consq Access to electrical supply				
S/guard Robust design				
R009 Any defects to be reported after shift to lamp repairer			Who CUS	Type O
R010 Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes			Who TS	Type M
Hazard What if cable gland is broken or removed	Category PH	Freq 4 Risk Priority 8	Sev 8	E
Cause Over tightening				
Consq Moisture ingress, reduced lighting				
S/guard Special tool required to tighten or remove				
R011 Any defects to be reported after shift to lamp repairer			Who CUS	Type O
R012 Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes			Who TS	Type M
Hazard What if there is moisture ingress into head piece	Category EEI	Freq 3 Risk Priority 7	Sev 7	E
Cause Poor maintenance				
Consq Poor light, failure of light				
S/guard Gasket in place and O rings, robust design				
R013 Any defects to be reported after shift to lamp repairer			Who CUS	Type O
R014 Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes			Who TS	Type M

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report

Hazard What if there is a cut cable	Category PH	Freq 2 Risk Priority 5	Sev 5	D
Cause Accidents and abuse				
Consq No light, sparking				
S/guard Robust material				
R015 Any defects to be reported after shift to lamp repairer			Who CUS	Type O
R016 Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes			Who TS	Type M
Hazard What if there is a broken exit cover (Outer lid) and retaining clip and screw	Category PH	Freq 2 Risk Priority 3	Sev 3	B
Cause Abuse and normal wear and tear				
Consq Terminals and Polly switch exposed, fatalities, injuries				
S/guard Retaining clip to prevent abuse. Improved design. Robust material(Polycarbonate).Special tool required for retaining clip				
R017 Any defects to be reported after shift to lamp repairer			Who CUS	Type O
R018 Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes			Who TS	Type M
Hazard What if cable clamp(side entry) is not fitted	Category OE&HF	Freq 3 Risk Priority4	Sev 4	B
Cause Poor maintenance				
Consq Can cause loose connections, light failure, sparking				
S/guard Assembly procedures available in lamp rooms				
R019 Any defects to be reported after shift to lamp repairer			Who CUS	Type O
R020 Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes			Who TS	Type M
Hazard What if the Polly Switch does not function properly	Category E&IM	Freq 4 Risk Priority 4	Sev 4	A
Cause Limited life, incorrect charging rate, poor assembly and maintenance				
Consq No light(Polly switch open). If Polly switch stays closed then can have fires and/or explosions				
S/guard Cable bulb and Polly switch tester available				
R021 Any defects to be reported after shift to lamp repairer			Who CUS	Type O
R022 Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes			Who TS	Type M

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report

Hazard	What if accumulator is cracked and worn	Category	Freq	4	Sev	C
		PH	Risk Priority	6		
Cause	Abuse					
Consq	Injury due to acid burns					
S/guard	Robust design					
	Any defects to be reported after shift to lamp repairer				Who	Type
R023					CUS	O
	Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes				Who	Type
R024					TS	M
Hazard	What if there is poor maintenance done on Cap Lamp	Category	Freq	1	Sev	A
		OE&HF	RiskPriority	1		
Cause	Not following procedures. Insufficient training					
Consq	Invalidation of legal requirements					
S/guard	Training and certification					
	User to ensure personnel are fully trained and certificated				Who	Type
R025					CUS	T
	User to make use of OEM training				Who	Type
R026					MD	T
Hazard	What if cable is incorrectly connected to accumulator terminals or head piece contacts	Category	Freq	4	Sev	E
		OE&HF	Risk Priority	8		
Cause	Negligence, insufficient training, human error					
Consq	Reverse polarity can result loss of capacity					
S/guard	Color coded cable, indications on terminals, installation instructions					
	Polarity of the head piece to be indicated on installation instructions				Who	Type
R027					TS	S
					Who	Type

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report

S02 **Leisure Lamp**

I01 **Provide illumination for leisure purposes**

Hazard What if the FNB supplied charger is not used

Category **Freq** 3 **Sev** E
OE&HF **Risk Priority**7

Cause Lost charger, charger faulty

Consq Damage to accumulator, overcharge

S/guard OEM charger supplied with kit

Use OEM supplied Charger and accessories
R028

Who **Type**
CUS MT

Who **Type**

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report

S03 Loco Light

I01 Provide illumination for underground tramming vehicles

Hazard What if charging point is faulty on loco light and/or charging rack

Category MP **Freq** 3 **Sev** B
Risk Priority 4

Cause Abuse, poor maintenance.

Consq Accumulators will be undercharged and will not last shift, fatalities, loss of production

S/guard LED indication on charging rack, visual check on point

Daily maintenance checks. All charging should be done in lamp room
R029

Who CUS **Type** S

MSA to compile Maintenance and Trouble Shooting Notes
R030

Who MD **Type** A

Hazard What if wiring to terminals is incorrectly connected

Category MP **Freq** 2 **Sev** D
Risk Priority 5

Cause Untrained personnel, human error, poor maintenance.

Consq Damaged accumulators. No light. Reverse charge on accumulator

S/guard LED indication on charging rack, light will not work, Polly switch prevents short circuit

Wiring diagram to be attached to T piece.
R031

Who TS **Type** S

MSA to compile Maintenance and Trouble Shooting Notes
R032

Who MD **Type** A

Hazard What if toggle switch is broken or missing

Category MP **Freq** 4 **Sev** B
Risk Priority 5

Cause Tampering, wear and tear, poor maintenance

Consq No light, fatalities, loss of production.

S/guard Lock washer fitted on switch

Lamps must be inspected everyday by responsible person
R033

Who CUS **Type** S

MSA to compile Maintenance and Trouble Shooting Notes
R034

Who MD **Type** A

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report

Hazard What if locking device (Allen key screw) is missing	Category MP	Freq 4	Sev E	E
Cause Tampering, wear and tear, poor maintenance			Risk Priority 8	
Consq Access to terminals and accumulator, wiring exposed				
S/guard Two locking devices fitted (Two Allen keys)				
R035 Lamps must be inspected everyday by responsible person			Who CUS	Type S
R036 MSA to compile Maintenance and Trouble Shooting Notes			Who MD	Type A
Hazard What if spacer (T piece) is missing	Category MP	Freq 4	Sev E	E
Cause Poor maintenance			Risk Priority 8	
Consq Damage to accumulator and to reflector due to excessive movement and vibration				
S/guard Secured to bottom casing by means of strapping				
R037 Proper maintenance			Who CUS	Type S
R038 MSA to compile Maintenance and Trouble Shooting Notes			Who MD	Type A
Hazard What if casing is broken	Category MP	Freq 4	Sev D	D
Cause Accidents			Risk Priority 7	
Consq Wiring is exposed				
S/guard Robust material				
R039 MSA to compile Maintenance and Trouble Shooting Notes			Who MD	Type A
			Who	Type
Hazard What if the Polly Switch does not function properly	Category E&IM	Freq 4	Sev A	A
Cause Limited life, incorrect charging rate, poor assembly and maintenance			Risk Priority 4	
Consq No light(Polly switch open). If Polly switch stays closed then can have fires and/or explosions				
S/guard Cable bulb and Polly switch tester available				
R040 Any defects to be reported after shift to lamp repairer			Who CUS	Type O
R041 MSA to compile Maintenance and Trouble Shooting Notes			Who MD	Type A

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report

Hazard	What if cable is incorrectly connected to accumulator terminals or head piece contacts	Category	Freq	4	Sev	E
		OE&HF	Risk Priority	8		
Cause	Negligence, insufficient training, human error					
Consq	Reverse polarity can result loss of capacity					
S/guard	Color coded cable, indications on terminals					
	Wiring diagram to be fitted to T piece				Who	Type
R042					CUS	S
	MSA to compile Maintenance and Trouble Shooting Notes				Who	Type
R043					MD	A
Hazard	What if accumulator is damaged	Category	Freq	4	Sev	C
		PH	Risk Priority	6		
Cause	Abuse, accidents					
Consq	Injury due to acid burns					
S/guard	Robust design					
	Any defects to be reported after shift to lamp repairer				Who	Type
R044					CUS	O
	MSA to compile Maintenance and Trouble Shooting Notes				Who	Type
R045					MD	A
Hazard	What if one of the bulbs fuse	Category	Freq	3	Sev	B
		MP	Risk Priority	4		
Cause	Limited life, abuse					
Consq	No light, fatalities, loss of equipment and production					
S/guard	Nil					
	Daily maintenance checks				Who	Type
R046					CUS	S
	MSA to compile Maintenance and Trouble Shooting Notes				Who	Type
R047					MD	A

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report

S04 CM remote adaptor

I01 Source of power for continuous miner remote control

Hazard What if water seal is not fitted during maintenance

Category MP **Freq** 4 **Sev** E
Risk Priority 8

Cause Poor maintenance, human error

Consq Dislodge the magnet which will result in no power to the remote

S/guard Nil

R048 Train personnel with regards to use. EPM to supply assembly instructions

Who EM **Type** S

Who **Type**

Hazard What if the inline fuse blows

Category E&M **Freq** 2 **Sev** B
Risk Priority 3

Cause Abuse, moisture, malfunction

Consq No power to remote control, loss of production

S/guard Nil

R049 Never remove connection from remote control and always disconnect on cap lamp side. Train personnel with regards to use

Who CUS **Type** S

Who **Type**

Hazard What if goose neck connector is not secured properly

Category E&M **Freq** 3 **Sev** E
Risk Priority 7

Cause Human error

Consq No power to remote control, loss of production

S/guard Magnetic reed switch will only engage if connection is in locked position

R050 Train personnel with regards to use

Who CUS **Type** S

Who **Type**

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report

Hazard What if dirt gets into female side of remote adaptor **Category** PH **Freq** 2 **Sev** 5 **D**

Cause Human error, abuse **Risk Priority 5**

Consq No power to remote control, loss of production, damage to connector

S/guard Dust cap supplied

Train personnel with regards to use **Who** CUS **Type** S

R051 **Who** **Type**

Hazard What if soldering of remote cable to goose neck connector is not done correctly **Category** PH **Freq** 2 **Sev** 5 **D**

Cause Human error, lack of training **Risk Priority 5**

Consq No power to remote control, loss of production.

S/guard Nil

Train personnel with regards to use. EPM to supply assembly instructions. **Who** CUS **Type** S

R052 **Who** **Type**

End of Report

SECTION 6

RECOMMENDATIONS (ORDERED BY TYPE)

UNDERGROUND ILLUMINATION

First National Battery

17 August 2001

Underground Illumination

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS

Recommendations (ordered by recommendation type)

Recommendation Type	A	Specify acceptance criteria	Risk Priority	
S03 I01 R030		MSA to compile Maintenance and Trouble Shooting Notes	Risk Priority	4
S03 I01 R032		MSA to compile Maintenance and Trouble Shooting Notes	Risk Priority	5
S03 I01 R034		MSA to compile Maintenance and Trouble Shooting Notes	Risk Priority	5
S03 I01 R036		MSA to compile Maintenance and Trouble Shooting Notes	Risk Priority	8
S03 I01 R038		MSA to compile Maintenance and Trouble Shooting Notes	Risk Priority	8
S03 I01 R039		MSA to compile Maintenance and Trouble Shooting Notes	Risk Priority	7
S03 I01 R041		MSA to compile Maintenance and Trouble Shooting Notes	Risk Priority	4
S03 I01 R043		MSA to compile Maintenance and Trouble Shooting Notes	Risk Priority	8
S03 I01 R045		MSA to compile Maintenance and Trouble Shooting Notes	Risk Priority	6
S03 I01 R047		MSA to compile Maintenance and Trouble Shooting Notes	Risk Priority	4

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Recommendations (ordered by recommendation type)

Recommendation Type			M	Update Operations manual		
S01	I01	R002		Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes	Risk Priority	1
S01	I01	R004		Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes	Risk Priority	4
S01	I01	R006		Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes	Risk Priority	4
S01	I01	R008		Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes	Risk Priority	4
S01	I01	R010		Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes	Risk Priority	5
S01	I01	R012		Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes	Risk Priority	8
S01	I01	R014		Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes	Risk Priority	7
S01	I01	R016		Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes	Risk Priority	5
S01	I01	R018		Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes	Risk Priority	3
S01	I01	R020		Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes	Risk Priority	4
S01	I01	R022		Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes	Risk Priority	4
S01	I01	R024		Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes	Risk Priority	6

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Recommendations (ordered by recommendation type)

Recommendation Type			MT	Marketing			
S02	I01	R028	Use OEM supplied Charger and accessories			Risk Priority	7

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Recommendations (ordered by recommendation type)

Recommendation Type			O	Operator Training			
S01	I01	R009		Any defects to be reported after shift to lamp repairer		Risk Priority	5
S01	I01	R011		Any defects to be reported after shift to lamp repairer		Risk Priority	8
S01	I01	R013		Any defects to be reported after shift to lamp repairer		Risk Priority	7
S01	I01	R015		Any defects to be reported after shift to lamp repairer		Risk Priority	5
S01	I01	R017		Any defects to be reported after shift to lamp repairer		Risk Priority	3
S01	I01	R019		Any defects to be reported after shift to lamp repairer		Risk Priority	4
S01	I01	R021		Any defects to be reported after shift to lamp repairer		Risk Priority	4
S01	I01	R023		Any defects to be reported after shift to lamp repairer		Risk Priority	6
S03	I01	R040		Any defects to be reported after shift to lamp repairer		Risk Priority	4
S03	I01	R044		Any defects to be reported after shift to lamp repairer		Risk Priority	6

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Recommendations (ordered by recommendation type)

Recommendation Type			S	Standard Required	Risk Priority	
S01	I01	R001		Employees to be made aware of dangers and consequences	Risk Priority	1
S01	I01	R003		Employees to be made aware of dangers and consequences	Risk Priority	4
S01	I01	R005		Employees to be made aware of dangers and consequences	Risk Priority	4
S01	I01	R007		Worker not allowed to be on his own	Risk Priority	4
S01	I01	R027		Polarity of the head piece to be indicated on installation instructions	Risk Priority	8
S03	I01	R029		Daily maintenance checks. All charging should be done in lamp room	Risk Priority	4
S03	I01	R031		Wiring diagram to be attached to T piece.	Risk Priority	5
S03	I01	R033		Lamps must be inspected everyday by responsible person	Risk Priority	5
S03	I01	R035		Lamps must be inspected everyday by responsible person	Risk Priority	8
S03	I01	R037		Proper maintenance	Risk Priority	8
S03	I01	R042		Wiring diagram to be fitted to T piece	Risk Priority	8
S03	I01	R046		Daily maintenance checks	Risk Priority	4
S04	I01	R048		Train personnel with regards to use. EPM to supply assembly instructions	Risk Priority	8
S04	I01	R049		Never remove connection from remote control and always disconnect on cap lamp side. Train personnel with regards to use	Risk Priority	3

Train personnel with regards to use				Risk	7
S04	I01	R050		Priority	
			Train personnel with regards to use	Risk	5
S04	I01	R051		Priority	
			Train personnel with regards to use. EPM to supply assembly instructions.	Risk	5
S04	I01	R052		Priority	

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Recommendations (ordered by recommendation type)

Recommendation Type			T	Technical Training			
S01	I01	R025		User to ensure personnel are fully trained and certificated		Risk Priority	1
S01	I01	R026		User to make use of OEM training		Risk Priority	1

End of Report

SECTION 6

RECOMMENDATIONS (ORDERED BY PRIORITY)

UNDERGROUND ILLUMINATION

First National Battery

17 August 2001

Underground Illumination

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS

Recommendations (ordered by priority)

Recommendation Priority 1

S01 I01 R001 Employees to be made aware of dangers and consequences **Type S**

S01 I01 R002 Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes **Type M**

S01 I01 R025 User to ensure personnel are fully trained and certificated **Type T**

S01 I01 R026 User to make use of OEM training **Type T**

Recommendation Priority 3

S01 I01 R017 Any defects to be reported after shift to lamp repairer **Type O**

S01 I01 R018 Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes **Type M**

S04 I01 R049 Never remove connection from remote control and always disconnect on cap lamp side. Train personnel with regards to use **Type S**

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Recommendations (ordered by priority)

Recommendation Priority 4

S01	I01	R003	Employees to be made aware of dangers and consequences	Type	S
S01	I01	R004	Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes	Type	M
S01	I01	R005	Employees to be made aware of dangers and consequences	Type	S
S01	I01	R006	Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes	Type	M
S01	I01	R007	Worker not allowed to be on his own	Type	S
S01	I01	R008	Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes	Type	M
S01	I01	R019	Any defects to be reported after shift to lamp repairer	Type	O
S01	I01	R020	Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes	Type	M
S01	I01	R021	Any defects to be reported after shift to lamp repairer	Type	O
S01	I01	R022	Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes	Type	M
S03	I01	R029	Daily maintenance checks. All charging should be done in lamp room	Type	S
S03	I01	R030	MSA to compile Maintenance and Trouble Shooting Notes	Type	A
S03	I01	R040	Any defects to be reported after shift to lamp repairer	Type	O
S03	I01	R041	MSA to compile Maintenance and Trouble Shooting Notes	Type	A
S03	I01	R046	Daily maintenance checks	Type	S
S03	I01	R047	MSA to compile Maintenance and Trouble Shooting Notes	Type	A

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Recommendations (ordered by priority)

Recommendation Priority 5

S01	I01	R009	Any defects to be reported after shift to lamp repairer	Type	O
S01	I01	R010	Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes	Type	M
S01	I01	R015	Any defects to be reported after shift to lamp repairer	Type	O
S01	I01	R016	Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes	Type	M
S03	I01	R031	Wiring diagram to be attached to T piece.	Type	S
S03	I01	R032	MSA to compile Maintenance and Trouble Shooting Notes	Type	A
S03	I01	R033	Lamps must be inspected everyday by responsible person	Type	S
S03	I01	R034	MSA to compile Maintenance and Trouble Shooting Notes	Type	A
S04	I01	R051	Train personnel with regards to use	Type	S
S04	I01	R052	Train personnel with regards to use. EPM to supply assembly instructions.	Type	S

Recommendation Priority 6

S01	I01	R023	Any defects to be reported after shift to lamp repairer	Type	O
S01	I01	R024	Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes	Type	M
S03	I01	R044	Any defects to be reported after shift to lamp repairer	Type	O
S03	I01	R045	MSA to compile Maintenance and Trouble Shooting Notes	Type	A

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Recommendations (ordered by priority)

Recommendation Priority 7

S01	I01	R013	Any defects to be reported after shift to lamp repairer	Type	O
S01	I01	R014	Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes	Type	M
S02	I01	R028	Use OEM supplied Charger and accessories	Type	MT
S03	I01	R039	MSA to compile Maintenance and Trouble Shooting Notes	Type	A
S04	I01	R050	Train personnel with regards to use	Type	S

Recommendation Priority 8

S01	I01	R011	Any defects to be reported after shift to lamp repairer	Type	O
S01	I01	R012	Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes	Type	M
S01	I01	R027	Polarity of the head piece to be indicated on installation instructions	Type	S
S03	I01	R035	Lamps must be inspected everyday by responsible person	Type	S
S03	I01	R036	MSA to compile Maintenance and Trouble Shooting Notes	Type	A
S03	I01	R037	Proper maintenance	Type	S
S03	I01	R038	MSA to compile Maintenance and Trouble Shooting Notes	Type	A
S03	I01	R042	Wiring diagram to be fitted to T piece	Type	S
S03	I01	R043	MSA to compile Maintenance and Trouble Shooting Notes	Type	A
S04	I01	R048	Train personnel with regards to use. EPM to supply assembly instructions	Type	S

End of Report

SECTION 6

WORKSHEET REPORT (SORTED BY WORK AREA AND RISK PRIORITY)

UNDERGROUND ILLUMINATION

First National Battery

17 August 2001

Underground Illumination

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS

Risk Assessment Worksheet Report sorted by Work Area and Risk Priority

S01 **Miners Cap Lamps**

I01 **Illumination of personal work area**

Hazard What if lock pin is tampered with

Category **Freq** **1** **Sev**
OE&HF Risk Priority1

Cause Illegal use of electricity supply

Consq Underground fires, explosion of flammable gas, fatalities and injuries, damage to equipment

S/guard Sealing wax to prevent tampering. Special tool required to remove lock pin

Employees to be made aware of dangers and consequences

R001

Who
CUS

Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes

R002

Who
Who
TS

Hazard What if there is poor maintenance done on Cap Lamp

Category **Freq** **1** **Sev**
OE&HF Risk Priority1

Cause Not following procedures. Insufficient training

Consq Invalidation of legal requirements

S/guard Training and certification

User to ensure personnel are fully trained and certificated

R025

Who
CUS

User to make use of OEM training

R026

Who
Who
MD

I01 **Illumination of personal work area**

Hazard What if there is a broken exit cover (Outer lid) and retaining clip and screw

Category **Freq** **2** **Sev**
PH Risk Priority 3

Cause Abuse and normal wear and tear

Consq Terminals and Polly switch exposed, fatalities, injuries

S/guard Retaining clip to prevent abuse. Improved design. Robust material (Polycarbonate). Special tool required for retaining clip

Any defects to be reported after shift to lamp repairer

R017

Who
CUS

Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes

R018

Who
Who
TS

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report sorted by Work Area and Risk Priority

I01 Illumination of personal work area

Hazard What if Lock Barrel is tampered with **Category** Freq 4 Sev
OE&HF Risk Priority4

Cause Illegal use of electricity supply

Consq Underground fires, explosion of flammable gas, fatalities and injuries, damage to equipment

S/guard Charging key must be used

Employees to be made aware of dangers and consequences

R003

Who
CUS

Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes

R004

Who
Who
TS

Hazard What if Switch Knob is tampered with

Category Freq 4 Sev
OE&HF Risk Priority4

Cause Illegal use of electricity supply

Consq Underground fires, explosion of flammable gas, fatalities and injuries, damage to equipment

S/guard Switch knob cannot be removed from outside

Employees to be made aware of dangers and consequences

R005

Who
CUS

Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes

R006

Who
Who
TS

Hazard What if the bulb fails

Category Freq 2 Sev
MP Risk Priority 4

Cause Limited life

Consq Worker has no light and can be injured

S/guard NIL

Worker not allowed to be on his own

R007

Who
CUS

Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes

R008

Who
Who
TS

Hazard What if cable clamp(side entry) is not fitted

Category Freq 3 Sev
OE&HF Risk Priority4

Cause Poor maintenance

Consq Can cause loose connections, light failure, sparking

S/guard Assembly procedures available in lamp rooms

Any defects to be reported after shift to lamp repairer

R019

Who
CUS

Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes

R020

Who
Who
TS

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report sorted by Work Area and Risk Priority

Hazard	What if the Polly Switch does not function properly	Category	Freq 4	Sev
		E&IM	Risk Priority 4	
Cause	Limited life, incorrect charging rate, poor assembly and maintenance			
Consq	No light(Polly switch open). If Polly switch stays closed then can have fires and/or explosions			
S/guard	Cable bulb and Polly switch tester available			
	Any defects to be reported after shift to lamp repairer			Who
R021				CUS
	Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes			Who
R022				Who
				TS
I01	Illumination of personal work area			
Hazard	What if there is a broken lens ring and head piece molding	Category	Freq 3	Sev
		PH	Risk Priority 5	
Cause	Lens ring and head pieces knocked hard and abused			
Consq	Access to electrical supply			
S/guard	Robust design			
	Any defects to be reported after shift to lamp repairer			Who
R009				CUS
	Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes			Who
R010				Who
				TS
Hazard	What if there is a cut cable	Category	Freq 2	Sev
		PH	Risk Priority 5	
Cause	Accidents and abuse			
Consq	No light, sparking			
S/guard	Robust material			
	Any defects to be reported after shift to lamp repairer			Who
R015				CUS
	Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes			Who
R016				Who
				TS
I01	Illumination of personal work area			
Hazard	What if accumulator is cracked and worn	Category	Freq 4	Sev
		PH	Risk Priority 6	
Cause	Abuse			
Consq	Injury due to acid burns			
S/guard	Robust design			
	Any defects to be reported after shift to lamp repairer			Who
R023				CUS
	Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes			Who
R024				Who
				TS

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report sorted by Work Area and Risk Priority

I01 Illumination of personal work area

Hazard	What if there is moisture ingress into head piece	Category	Freq	3	Sev
		EEL			Risk Priority 7
Cause	Poor maintenance				
Consq	Poor light, failure of light				
S/guard	Gasket in place and O rings, robust design				
	Any defects to be reported after shift to lamp repairer				
R013					Who CUS
	Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes				
R014					Who Who TS

I01 Illumination of personal work area

Hazard	What if cable gland is broken or removed	Category	Freq	4	Sev
		PH			Risk Priority 8
Cause	Over tightening				
Consq	Moisture ingress, reduced lighting				
S/guard	Special tool required to tighten or remove				
	Any defects to be reported after shift to lamp repairer				
R011					Who CUS
	Safety rules to be incorporated in Miners Cap Lamp Maintenance and Trouble Shooting Notes				
R012					Who Who TS

Hazard	What if cable is incorrectly connected to accumulator terminals or head piece contacts	Category	Freq	4	Sev
		OE&HF			Risk Priority 8
Cause	Negligence, insufficient training, human error				
Consq	Reverse polarity can result loss of capacity				
S/guard	Color coded cable, indications on terminals, installation instructions				
	Polarity of the head piece to be indicated on installation instructions				
R027					Who TS
					Who

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report sorted by Work Area and Risk Priority

S02 **Leisure Lamp**

I01 **Provide illumination for leasure purposes**

Hazard What if the FNB supplied charger is not used

Category **Freq** **3** **Sev**
OE&HF **Risk Priority**7

Cause Lost charger, charger faulty

Consq Damage to accumulator, overcharge

S/guard OEM charger supplied with kit

Use OEM supplied Charger and accessories

R028

Who
CUS

Who

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report sorted by Work Area and Risk Priority

S03 Loco Light

I01 Provide illumination for underground tramping vehicles

Hazard What if charging point is faulty on loco light and/or charging rack

Category **Freq** 3 **Sev**
MP **Risk Priority** 4

Cause Abuse, poor maintenance.

Consq Accumulators will be undercharged and will not last shift, fatalities, loss of production

S/guard LED indication on charging rack, visual check on point

Daily maintenance checks. All charging should be done in lamp room

R029

Who
CUS

MSA to compile Maintenance and Trouble Shooting Notes

R030

Who
Who
MD

Hazard What if the Polly Switch does not function properly

Category **Freq** 4 **Sev**
E&IM **Risk Priority** 4

Cause Limited life, incorrect charging rate, poor assembly and maintenance

Consq No light(Polly switch open). If Polly switch stays closed then can have fires and/or explosions

S/guard Cable bulb and Polly switch tester available

Any defects to be reported after shift to lamp repairer

R040

Who
CUS

MSA to compile Maintenance and Trouble Shooting Notes

R041

Who
Who
MD

Hazard What if one of the bulbs fuse

Category **Freq** 3 **Sev**
MP **Risk Priority** 4

Cause Limited life, abuse

Consq No light, fatalities, loss of equipment and production

S/guard Nil

Daily maintenance checks

R046

Who
CUS

MSA to compile Maintenance and Trouble Shooting Notes

R047

Who
Who
MD

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report sorted by Work Area and Risk Priority

I01 Provide illumination for underground tramming vehicles

Hazard What if wiring to terminals is incorrectly connected **Category** **Freq** **2** **Sev**
MP **Risk Priority** 5

Cause Untrained personnel, human error, poor maintenance.

Consq Damaged accumulators. No light. Reverse charge on accumulator

S/guard LED indication on charging rack, light will not work, Polly switch prevents short circuit

Wiring diagram to be attached to T piece.

R031

Who
TS

MSA to compile Maintenance and Trouble Shooting Notes

R032

Who
Who
MD

Hazard What if toggle switch is broken or missing **Category** **Freq** **4** **Sev**
MP **Risk Priority** 5

Cause Tampering, wear and tear, poor maintenance

Consq No light, fatalities, loss of production.

S/guard Lock washer fitted on switch

Lamps must be inspected everyday by responsible person

R033

Who
CUS

MSA to compile Maintenance and Trouble Shooting Notes

R034

Who
Who
MD

I01 Provide illumination for underground tramming vehicles

Hazard What if accumulator is damaged **Category** **Freq** **4** **Sev**
PH **Risk Priority** 6

Cause Abuse, accidents

Consq Injury due to acid burns

S/guard Robust design

Any defects to be reported after shift to lamp repairer

R044

Who
CUS

MSA to compile Maintenance and Trouble Shooting Notes

R045

Who
Who
MD

I01 Provide illumination for underground tramming vehicles

Hazard What if casing is broken **Category** **Freq** **4** **Sev**
MP **Risk Priority** 7

Cause Accidents

Consq Wiring is exposed

S/guard Robust material

MSA to compile Maintenance and Trouble Shooting Notes

R039

Who
MD

Who

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report sorted by Work Area and Risk Priority

I01 Provide illumination for underground trammng vehicles

<p>Hazard What if locking device (Allen key screw) is missing</p> <p>Cause Tampering, wear and tear, poor maintenance</p> <p>Consq Access to terminals and accumulator, wiring exposed</p> <p>S/guard Two locking devices fitted (Two Allen keys)</p> <p>Lamps must be inspected everyday by responsible person</p> <p>R035</p> <p>MSA to compile Maintenance and Trouble Shooting Notes</p> <p>R036</p>	<p>Category MP</p> <p>Freq 4</p> <p>Sev Risk Priority 8</p>	<p>Who CUS</p> <p>Who MD</p>
<p>Hazard What if spacer (T piece) is missing</p> <p>Cause Poor maintenance</p> <p>Consq Damage to accumulator and to reflector due to excessive movement and vibration</p> <p>S/guard Secured to bottom casing by means of strapping</p> <p>Proper maintenance</p> <p>R037</p> <p>MSA to compile Maintenance and Trouble Shooting Notes</p> <p>R038</p>	<p>Category MP</p> <p>Freq 4</p> <p>Sev Risk Priority 8</p>	<p>Who CUS</p> <p>Who MD</p>
<p>Hazard What if cable is incorrectly connected to accumulator terminals or head piece contacts</p> <p>Cause Negligence, insufficient training, human error</p> <p>Consq Reverse polarity can result loss of capacity</p> <p>S/guard Color coded cable, indications on terminals</p> <p>Wiring diagram to be fitted to T piece</p> <p>R042</p> <p>MSA to compile Maintenance and Trouble Shooting Notes</p> <p>R043</p>	<p>Category OE&HF</p> <p>Freq 4</p> <p>Sev Risk Priority8</p>	<p>Who CUS</p> <p>Who MD</p>

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report sorted by Work Area and Risk Priority

S04 CM remote adaptor

I01 Source of power for continuous miner remote control

Hazard What if the inline fuse blows

Category Freq 2 Sev
 E&IM Risk Priority 3

Cause Abuse, moisture, malfunction

Consq No power to remote control, loss of production

S/guard Nil

R049 Never remove connection from remote control and always disconnect on cap lamp side. Train personnel with regards to use

Who

CUS

Who

I01 Source of power for continuous miner remote control

Hazard What if dirt gets into female side of remote adaptor

Category Freq 2 Sev
 PH Risk Priority 5

Cause Human error, abuse

Consq No power to remote control, loss of production, damage to connector

S/guard Dust cap supplied

R051 Train personnel with regards to use

Who

CUS

Who

Hazard What if soldering of remote cable to goose neck connector is not done correctly

Category Freq 2 Sev
 PH Risk Priority 5

Cause Human error, lack of training

Consq No power to remote control, loss of production.

S/guard Nil

R052 Train personnel with regards to use. EPM to supply assembly instructions.

Who

CUS

Who

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report sorted by Work Area and Risk Priority

I01 **Source of power for continuous miner remote control**

Hazard What if goose neck connector is not secured properly

Category **Freq** 3 **Sev**
E&IM Risk Priority 7

Cause Human error

Consq No power to remote control, loss of production

S/guard Magnetic reed switch will only engage if connection is in locked position

Train personnel with regards to use

R050

Who
CUS

Who

I01 **Source of power for continuous miner remote control**

Hazard What if water seal is not fitted during maintenance

Category **Freq** 4 **Sev**
MP Risk Priority 8

Cause Poor maintenance, human error

Consq Dislodge the magnet which will result in no power to the remote

S/guard Nil

Train personnel with regards to use. EPM to supply assembly instructions

R048

Who
EM

Who

End of Report

SECTION 7

RISK ASSESSMENT DATA ANALYSIS

TOX AND FLAM ALARMS

7.0 TOX AND FLAM ALARMS

RISK ASSESSMENT DATA ANALYSIS

In this section the data contained in the Risk Assessment database has been extracted and summarised in various formats for graphical display.

GRAPH 1 - RISK PROFILE

Two of the higher risks are identified as follows:

- Seals left out on the Tox Alarm
- Seals left out on the Flam Alarm

The major focus concerning these hazards should be that the users carry out supplier recommended maintenance and inspection procedures and should use OEM parts. Also of significance is that regular training be carried out by the customer and that users are aware of the hazards and dangers and also to follow the supplier's installation and maintenance procedures.

GRAPH 2 - SUMMARY OF RISKS BY "WHAT IF" CATEGORY

The only two hazards identified are related to operator errors or human factors (10/17) and Physical hazards in the operation, use and maintenance of the equipment (7/17). Similarly, in order to reduce the risk of equipment malfunction procedures must be followed by users and regular training to be carried out by the customer.


GRAPH 3 - SUMMARY OF RECOMMENDATIONS BY TYPE

This graph indicates that the majority of recommendations are also related to user standards required to ensure that the suppliers safety and installation procedures are followed as well as recommended operator training for both the Tox and Flam alarms. There is also the need to ensure that the appropriate Maintenance Programmes are in place.

GRAPH 4 - SUMMARY OF RECOMMENDATIONS BY RESPONSIBILITY


From this analysis it is again evident that majority of responsibilities are with the customer in order to ensure that there is regular re training of users and is vital that recommended maintenance and inspection procedures are followed.

Graph 1




Graph 2

**First National Battery - Summary of Hazards By "What If" Category
Tox and Flam Alarms**




Graph 3

**First National Battery - Recommendations by Type
Tox and Flam Alarms**



Graph 4

**First National Battery - Recommendations Responsibility Graph
Tox and Flam Alarms**



SECTION 7

RISK ASSESSMENT WORKSHEET REPORT

TOX AND FLAM ALARMS

First National Battery

17 August 2001

Tox and Flam Alarms

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS

Risk Assessment Worksheet Report

S01 Tox Alarms

I01 Carbon Monoxide Detector

Hazard What if sensor cell ages

Category Freq 3 Sev E
PH Risk Priority 7

Cause Limited life of sensor cell

Consq Gradual degradation of performance

S/guard Calibration

Who Type

Who Type

Hazard What if re calibration is not done

Category Freq 3 Sev C
OE&HF Risk Priority5

Cause Not following procedures

Consq Wrong reading and undetected deterioration of performance

S/guard Required safeguards are stipulated in training materials and video

Who Type

Who Type

Hazard What if housing is cracked or damaged

Category Freq 3 Sev B
PH Risk Priority 4

Cause Abuse by wearer

Consq Water ingress

S/guard Robustness, wearer trained to do daily inspections, daily tests

Who Type

Who Type

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report

Hazard What if incorrect bulb holder is used **Category** OE&HF **Freq** 3 **Sev** B **B**
Cause Use of incorrect spare part during maintenance **Risk Priority**4
Consq Wearer would not be able to see warning signal
S/guard Daily checks as per OEM instructions
Regular retraining of personnel (users and lamp room personnel) **Who** CUS **Type** O
R001 **Who** **Type**

Hazard What if seals are left out **Category** OE&HF **Freq** 2 **Sev** B **B**
Cause Negligence, not following procedures, poor training **Risk Priority**3
Consq Water or moisture ingress causing eventual failure
S/guard Quality control, training manuals and video
Use of OEM parts. Carry out recommended maintenance and inspection procedures **Who** CUS **Type** S
R002 **Who** **Type**

Hazard What if the filter is blocked **Category** PH **Freq** 4 **Sev** B **B**
Cause Dirt, mud **Risk Priority** 5
Consq Progressive degradation in response time, catastrophic failure if totally covered in mud.
S/guard Design to be dust proof, operators are instructed to clean unit
Carry out recommended handling and inspection procedures **Who** CUS **Type** S
R003 **Who** **Type**

Hazard What if there is poisoning of electrochemical cell **Category** PH **Freq** 3 **Sev** B **B**
Cause Incorrect cleaning procedures, abuse **Risk Priority** 4
Consq Failure of the sensor cell
S/guard Training manual and video
Ongoing training of operators **Who** CUS **Type** O
R004 **Who** **Type**

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report

Hazard What if maintenance is not done **Category** Freq 2 Sev C
OE&HF Risk Priority5

Cause not following procedures as laid down by OEM

Consq failure of equipment

S/guard Required safeguards are stipulated in training materials and video

Regular (at least annually) retraining of maintenance personnel **Who Type**
CUS MP

R005 **Who Type**
Who Type

Hazard What if the instrument is subjected to chemical solvents **Category** Freq 3 Sev D
OE&HF Risk Priority5

Cause Incorrect cleaning procedures

Consq Cover becomes brittle and will crack

S/guard Required safeguards are stipulated in training materials and video

Regular retraining of personnel (users and lamp room personnel) **Who Type**
CUS O

R006 **Who Type**
Who Type

Hazard What if maintenance is not done **Category** Freq 2 Sev C
OE&HF Risk Priority5

Cause not following procedures as laid down by OEM

Consq failure of equipment

S/guard Required safeguards are stipulated in training materials and video

Regular (at least annually) retraining of maintenance personnel **Who Type**
CUS MP

R007 **Who Type**
Who Type

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report

S02 **Flam Alarm**

I01 **Flamable Gas Detector**

Hazard What if re calibration is not done

Category Freq 3 Sev C
OE&HF Risk Priority5

Cause Not following procedures

Consq Wrong reading and undetected deterioration of performance

S/guard Required safeguards are stipulated in training materials and video

Who Type

Who Type

Hazard What if incorrect bulb holder is used

Category Freq 3 Sev B
OE&HF Risk Priority4

Cause Use of incorrect spare part during maintenance

Consq Wearer would not be able to see warning signal

S/guard Daily checks as per OEM instructions

Regular retraining of personnel (users and lamp room personnel)
R008

Who Type
CUS O

Who Type

Hazard What if the instrument is subjected to chemical solvents

Category Freq 3 Sev D
OE&HF Risk Priority5

Cause Incorrect cleaning procedures

Consq Cover becomes brittle and will crack

S/guard Required safeguards are stipulated in training materials and video

Regular retraining of personnel (users and lamp room personnel)
R009

Who Type
CUS O

Who Type

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report

Hazard What if there is poisoning of pellister sensor **Category** Freq 3 Sev B
PH Risk Priority 4

Cause Incorrect cleaning procedures of flam alarm and other lamp room equipment, abuse. Exposure to inappropriate chemicals during use

Consq Failure of the pellister sensor

S/guard Training manual and video

Ongoing training of operators **Who Type**
R010 CUS O

Who Type

Hazard What if the filters are blocked **Category** Freq 4 Sev B
PH Risk Priority 4

Cause Dirt, mud

Consq Progressive degradation in response time, catastrophic failure if totally covered in mud.

S/guard Design to be dust proof, operators are instructed to clean unit

Carry out recommended handling and inspection procedures **Who Type**
R011 CUS S

Who Type

Hazard What if seals are left out **Category** Freq 2 Sev B
OE&HF Risk Priority3

Cause Negligence, not following procedures, poor training

Consq Water or moisture ingress causing eventual failure. The unit may no longer be explosion protected

S/guard Quality control, training manuals and video

Use of OEM parts. Carry out recommended maintenance and inspection procedures **Who Type**
R012 CUS S

Who Type

Hazard What if housing is cracked or damaged **Category** Freq 3 Sev B
PH Risk Priority 4

Cause Abuse by wearer

Consq Water ingress and unit may no longer be explosion protected

S/guard Robustness, wearer trained to do daily inspections, daily tests

Regular re training of personnel. **Who Type**
R013 CUS O

Who Type

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report

End of Report

SECTION 7

RECOMMENDATIONS (ORDERED BY PRIORITY)

TOX AND FLAM ALARMS

First National Battery

17 August 2001

Tox and Flam Alarms

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS

Recommendations (ordered by priority)

Recommendation Priority 3

S01 I01 R002 Use of OEM parts. Carry out recommended maintenance and inspection procedures **Type S**

S02 I01 R012 Use of OEM parts. Carry out recommended maintenance and inspection procedures **Type S**

Recommendation Priority 4

S01 I01 R001 Regular retraining of personnel (users and lamp room personnel) **Type O**

S01 I01 R004 Ongoing training of operators **Type O**

S02 I01 R008 Regular retraining of personnel (users and lamp room personnel) **Type O**

S02 I01 R010 Ongoing training of operators **Type O**

S02 I01 R011 Carry out recommended handling and inspection procedures **Type S**

S02 I01 R013 Regular re training of personnel. **Type O**

Recommendation Priority 5

S01 I01 R003 Carry out recommended handling and inspection procedures **Type S**

S01 I01 R005 Regular (at least annually) retraining of maintenance personnel **Type MP**

S01 I01 R006 Regular retraining of personnel (users and lamp room personnel) **Type O**

S01 I01 R007 Regular (at least annually) retraining of maintenance personnel **Type MP**

S02 I01 R009 Regular retraining of personnel (users and lamp room personnel) **Type O**

End of Report

SECTION 7

WORKSHEET REPORT (SORTED BY WORK AREA AND RISK PRIORITY)

TOX AND FLAM ALARMS

First National Battery

17 August 2001

Tox and Flam Alarms

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS Risk Assessment Worksheet Report sorted by Work Area and Risk Priority

S01 Tox Alarms

I01 Carbon Monoxide Detector or monitor

Hazard What if seals are left out

Category **Freq** **2** **Sev** **B**
OE&HF Risk Priority 3

Cause Negligence, not following procedures, poor training

Consq Water or moisture ingress causing eventual failure

S/guard Quality control, training manuals and video

Use of OEM parts. Carry out recommended maintenance and inspection procedures

R002

Who **Type**
CUS S

Who **Type**

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report sorted by Work Area and Risk Priority

I01 Carbon Monoxide Detector or monitor

Hazard What if housing is cracked or damaged

Category Freq 3 Sev B
 PH Risk Priority 4

Cause Abuse by wearer

Consq Water ingress

S/guard Robustness, wearer trained to do daily inspections, daily tests

Who **Type**

Who **Type**

Hazard What if incorrect bulb holder is used

Category Freq 3 Sev B
 OE&HF Risk Priority 4

Cause Use of incorrect spare part during maintenance

Consq Wearer would not be able to see warning signal

S/guard Daily checks as per OEM instructions

Regular retraining of personnel (users and lamp room personnel)

R001

Who **Type**
 CUS O

Who **Type**

Hazard What if there is poisoning of electrochemical cell

Category Freq 3 Sev B
 PH Risk Priority 4

Cause Incorrect cleaning procedures, abuse

Consq Failure of the sensor cell

S/guard Training manual and video

Ongoing training of operators

R004

Who **Type**
 CUS O

Who **Type**

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report sorted by Work Area and Risk Priority

I01 Methane Detector

Hazard What if re calibration is not done

Category OE&HF **Freq** 3 **Sev** C
Risk Priority 5

Cause Not following procedures

Consq Wrong reading and undetected deterioration of performance

S/guard Required safeguards are stipulated in training materials and video

Who **Type**

Who **Type**

Hazard What if the filter is blocked

Category PH **Freq** 4 **Sev** B
Risk Priority 5

Cause Dirt, mud

Consq Progressive degradation in response time, catastrophic failure if totally covered in mud.

S/guard Design to be dust proof, operators are instructed to clean unit

Carry out recommended handling and inspection procedures

R003

Who **Type**
 CUS S

Who **Type**

Hazard What if maintenance is not done

Category OE&HF **Freq** 2 **Sev** C
Risk Priority 5

Cause not following procedures as laid down by OEM

Consq failure of equipment

S/guard Required safeguards are stipulated in training materials and video

Regular (at least annually) retraining of maintenance personnel

R005

Who **Type**
 CUS MP

Who **Type**

Hazard What if the instrument is subjected to chemical solvents

Category OE&HF **Freq** 3 **Sev** D
Risk Priority 5

Cause Incorrect cleaning procedures

Consq Cover becomes brittle and will crack

S/guard Required safeguards are stipulated in training materials and video

Regular retraining of personnel (users and lamp room personnel)

R006

Who **Type**
 CUS O

Who **Type**

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report sorted by Work Area and Risk Priority

Hazard What if maintenance is not done **Category** OE&HF **Freq** 2 **Sev** C
Risk Priority 5

Cause not following procedures as laid down by OEM

Consq failure of equipment

S/guard Required safeguards are stipulated in training materials and video

Regular (at least annually) retraining of maintenance personnel **Who** CUS **Type** MP

R007 **Who** **Type**

I01 Carbon Monoxide Detector

Hazard What if sensor cell ages **Category** PH **Freq** 3 **Sev** E
Risk Priority 7

Cause Limited life of sensor cell

Consq Gradual degradation of performance

S/guard Calibration **Who** **Type**

Who **Type**

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report sorted by Work Area and Risk Priority

S02 **Flam Alarm**

I01 **Flamable Gas Detector**

Hazard What if seals are left out

Category **Freq** 2 **Sev** B
OE&HF **Risk Priority** 3

Cause Negligence, not following procedures, poor training

Consq Water or moisture ingress causing eventual failure. The unit may no longer be explosion protected

S/guard Quality control, training manuals and video

Use of OEM parts. Carry out recommended maintenance and inspection procedures

R012

Who **Type**
CUS S

Who **Type**

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report sorted by Work Area and Risk Priority

I01 Flamable Gas Detector

Hazard What if incorrect bulb holder is used

Category Freq 3 Sev B
 OE&HF Risk Priority 4

Cause Use of incorrect spare part during maintenance

Consq Wearer would not be able to see warning signal

S/guard Daily checks as per OEM instructions

Regular retraining of personnel (users and lamp room personnel)

Who Type
 CUS O

R008

Who Type

Hazard What if there is poisoning of pellister sensor

Category Freq 3 Sev B
 PH Risk Priority 4

Cause Incorrect cleaning procedures of flam alarm and other lamp room equipment, abuse. Exposure to inappropriate chemicals during

Consq Failure of the pellister sensor

S/guard Training manual and video

Ongoing training of operators

Who Type
 CUS O

R010

Who Type

Hazard What if the filters are blocked

Category Freq 4 Sev B
 PH Risk Priority 4

Cause Dirt, mud

Consq Progressive degradation in response time, catastrophic failure if totally covered in mud.

S/guard Design to be dust proof, operators are instructed to clean unit

Carry out recommended handling and inspection procedures

Who Type
 CUS S

R011

Who Type

Hazard What if housing is cracked or damaged

Category Freq 3 Sev B
 PH Risk Priority 4

Cause Abuse by wearer

Consq Water ingress and unit may no longer be explosion protected

S/guard Robustness, wearer trained to do daily inspections, daily tests

Regular re training of personnel.

Who Type
 CUS O

R013

Who Type

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report sorted by Work Area and Risk Priority

I01 Flamable Gas Detector

Hazard What if re calibration is not done

Category **Freq** 3 **Sev** C
OE&HF **Risk Priority** 5

Cause Not following procedures

Consq Wrong reading and undetected deterioration of performance

S/guard Required safeguards are stipulated in training materials and video

Who **Type**

Who **Type**

Hazard What if the instrument is subjected to chemical solvents

Category **Freq** 3 **Sev** D
OE&HF **Risk Priority** 5

Cause Incorrect cleaning procedures

Consq Cover becomes brittle and will crack

S/guard Required safeguards are stipulated in training materials and video

Regular retraining of personnel (users and lamp room personnel)

R009

Who **Type**
CUS O

Who **Type**

End of Report

SECTION 8

RISK ASSESSMENT DATA ANALYSIS

STANDBY BATTERIES

8.0 STANDBY BATTERIES

RISK ASSESSMENT DATA ANALYSIS

In this section the data contained in the Risk Assessment database has been extracted and summarised in various formats for graphical display.

GRAPH 1 - RISK PROFILE

Three of the higher risks have been identified as follows:

- Battery abuse and poor maintenance
- Battery room inadequately ventilated
- Commissioning not carried out properly

The major focus concerning these hazards should be that the users carry out supplier recommended safety, maintenance and inspection procedures and to follow supplier commissioning instructions. Also FNB is to combine all safety rules regarding the equipment under one section in their Installation and Safety Instructions. Also charging procedures are to be followed at all times.

GRAPH 2 - SUMMARY OF RISKS BY “WHAT IF” CATEGORY

The three hazards identified are related to operator errors or human factors external effects and physical hazards in the operation, use and maintenance of the equipment. The batteries need to be commissioned according to correct procedures whenever new ones are installed. Also the correct handling must be carried out to ensure that acid spillage is avoided and proper transportation is carried out.

GRAPH 3 - SUMMARY OF RECOMMENDATIONS BY TYPE


This graph indicates that the majority of recommendations are related to user updating operator manuals, standards and procedures for this type of equipment. There is also the need to ensure that the appropriate Maintenance Programmes are in place.

GRAPH 4 - SUMMARY OF RECOMMENDATIONS BY RESPONSIBILITY

The main responsibilities are with the customer to ensure that safety rules as laid out in the supplier Installation and Maintenance instructions are adhered to. There are also tasks allocated to the FNB Technical Service Manager to ensure that the safety rules pertaining to standby batteries are incorporated in one section in their manuals.


Graph 1

**First National Battery - Risk Profile
Standby Batteries**




Graph 2

First National Battery - Summary of Hazards By "What If" Category Standby Batteries




Graph 3

**First National Battery - Recommendations by Type
Standby Batteries**



Graph 4

**First National Battery - Recommendations Responsibility Graph
Standby Batteries**



SECTION 8

RISK ASSESSMENT WORKSHEET REPORT

STANDBY BATTERIES

First National Battery

17 August 2001

Standby Batteries

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS

Risk Assessment Worksheet Report

S01 Standby Batteries

I01 Provide standby power to equipment

Hazard What if batteries are overcharged

Category Freq 3 Sev B
OE&HF Risk Priority4

Cause Charger faulty or incorrectly set

Consq Overheating, damage to product.

S/guard Charging procedure and instructions

Charging procedure and instructions must be followed at all times
R001

Who Type
MM T

Who Type

Hazard What if cells and acid are transported and/or stored incorrectly

Category Freq 2 Sev D
PH Risk Priority 5

Cause Incorrect material handling

Consq Acid spillage, short circuit, toppling over

S/guard Special containers for acid. PPE's, strapping in place and uprights

Transportation and storage to comply with OSH act and Lead regulations (Refer to Package and Transport and Storage) also refer to installation and maintenance procedures
R002

Who Type
EM S

Who Type

Hazard What if commissioning is not carried out properly

Category Freq 1 Sev C
OE&HF Risk Priority3

Cause Not following commissioning procedures

Consq Reduction in battery life

S/guard Detailed commissioning procedures in FNB Installation and Maintenance Instructions.

Follow commissioning instructions
R003

Who Type
CUS S

Installation and Maintenance and Safety instructions to be included in each delivery. FNB to combine all safety rules in one paragraph in Installation and Maintenance and Safety instructions. Add pictorial safety rules in manual
R004

Who Type
TS M

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report

Hazard	What if exposed terminals are touched	Category	Freq	4	Sev	B
		EEL	Risk Priority	5		
Cause	Unauthorized personnel working on equipment, human error					
Consq	Electric shock, fatality					
S/guard	Hazards identified in FNB Installation and Maintenance Instructions.					
	Safety rules as laid out in Installation and Maintenance instruction to be followed.				Who	Type
R005					CUS	P
	Installation and Maintenance and Safety instructions to be included in each delivery. FNB to combine all safety rules in one paragraph in Installation and Maintenance and Safety instructions. Add pictorial safety rules in manual				Who	Type
R006					TS	M
Hazard	What if acid is spilled	Category	Freq	3	Sev	D
		OE&HF	Risk Priority	6		
Cause	Battery is mishandled, dropped, bumped, collisions or exploding					
Consq	Injuries, damaged equipment due to corrosion					
S/guard	Alkaline neutralizer to be used on spillage e.g.. hydrated lime					
	Follow the battery maintenance instruction and procedures in case of injury				Who	Type
R007					CUS	MP
					Who	Type
Hazard	What if there is a battery abuse, and poor maintenance	Category	Freq	4	Sev	A
		OE&HF	Risk Priority	1		
Cause	Poor maintenance and improper usage					
Consq	Premature failure, fatalities					
S/guard	Follow maintenance and instruction manual as indicated in First National Battery 'Standby Power Batteries' manual					
	Follow the battery maintenance instruction and procedures				Who	Type
R008					CUS	MP
					Who	Type
Hazard	What if battery room is inadequately ventilated	Category	Freq	2	Sev	A
		EEL	Risk Priority	2		
Cause	Poor design or not adhering to standard engineering practices					
Consq	Explosion causing a fatality, spillage of acid, injury, material damage,					
S/guard	Hazards identified in FNB Installation and Maintenance Instructions. Engineering note available on request					
	Safety rules as laid out in Installation and Maintenance instruction to be followed.				Who	Type
R009					CUS	P
	Installation and Main and Safety instructions to be included in each delivery. FNB to combine all safety rules in one paragraph in Installation and Maintenance and Safety instructions. Add pictorial safety rules in manual				Who	Type
R010					TS	M

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS

Risk Assessment Worksheet Report

End of Report

SECTION 8

WORKSHEET REPORT (SORTED BY WORK AREA AND RISK PRIORITY)

STANDBY BATTERIES

First National Battery

17 August 2001

Standby Batteries

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS **Risk Assessment Worksheet Report sorted by Work Area and Risk Priority**

S01 Standby Batteries

I01 Provide standby power to equipment

Hazard What if there is a battery abuse, and poor maintenance **Category** Freq 4 Sev
OE&HF Risk Priority

Cause Poor maintenance and improper usage

Consq Premature failure, fatalities

S/guard Follow maintenance and instruction manual as indicated in First National Battery 'Standby Power Batteries' manual

Follow the battery maintenance instruction and procedures

R008

Who
CUS

Who
Type

I01 Provide standby power to equipment

Hazard What if battery room is inadequately ventilated **Category** Freq 2 Sev
EEI Risk Priority

Cause Poor design or not adhering to standard engineering practices

Consq Explosion causing a fatality, spillage of acid, injury, material damage,

S/guard Hazards identified in FNB Installation and Maintenance Instructions. Engineering note available on request

Safety rules as laid out in Installation and Maintenance instruction to be followed.

R009

Who
CUS

Installation and Main and Safety instructions to be included in each delivery. FNB to combine all safety rules in one

Type

Who

R010 paragraph in Installation and Maintenance and Safety instructions. Add pictorial safety rules in manual

Type

Who

TS M

I01 Provide standby power to equipment

Hazard What if commissioning is not carried out properly **Category** Freq 1 Sev
OE&HF Risk Priority

Cause Not following commissioning procedures

Consq Reduction in battery life

S/guard Detailed commissioning procedures in FNB Installation and Maintenance Instructions.

Follow commissioning instructions

R003

Who
CUS

Installation and Maintenance and Safety instructions to be included in each delivery. FNB to combine all safety

Type

Who

R004 rules in one paragraph in Installation and Maintenance and Safety instructions. Add pictorial safety rules in manual

Type

Who

TS M

RISK ASSESSMENT OF TECHNICAL / PROCESS OPERATIONS
Risk Assessment Worksheet Report sorted by Work Area and Risk Priority

I01 Provide standby power to equipment

Hazard What if batteries are overcharged	Category OE&HF	Freq 3	Sev
		Risk Priority	
Cause Charger faulty or incorrectly set			
Consq Overheating, damage to product.			
S/guard Charging procedure and instructions			
			Who
R001			MM
			Who
			Type

I01 Provide standby power to equipment

Hazard What if cells and acid are transported and/or stored incorrectly	Category PH	Freq 2	Sev
		Risk Priority	
Cause Incorrect material handling			
Consq Acid spillage, short circuit, toppling over			
S/guard Special containers for acid. PPE's, strapping in place and uprights			
			Who
R002			EM
			Who
			Type

Hazard What if exposed terminals are touched	Category EEI	Freq 4	Sev
		Risk Priority	
Cause Unauthorized personnel working on equipment, human error			
Consq Electric shock, fatality			
S/guard Hazards identified in FNB Installation and Maintenance Instructions.			
			Who
R005			CUS
			Who
R006			Who
Type			TS M

I01 Provide power to mobile equipment

Hazard What if acid is spilled	Category OE&HF	Freq 3	Sev
		Risk Priority	
Cause Battery is mishandled, dropped, bumped, collisions or exploding			
Consq Injuries, damaged equipment due to corrosion			
S/guard Alkaline neutralizer to be used on spillage e.g.. hydrated lime			
			Who
R007			CUS
			Who
			Type

End of Report

SECTION 9

TEAM MEMBERS

First National Battery

17 August 2001

Risk Assessment Team Details

FIRST NAME	SURNAME	POSITION	DEPARTMENT	EXP
Charles	van Aswegen	Plant Engineering Manager	Engineering	6
Jose	Pedregal	Production Manager	Production	23
Chris	Wheeler	Regional Manager	Marketing	16
Dick	Bakker	Mining	IRCA	38
Eugene	Pininski	Facilitator	IRCA	21
Hector	King	Sales Consultant	Sales	9
Johan	Prinsloo	Manager	Sybotec	13
Alan	Brodie	Engineering Manager	Spero	21

End of Report